


Job: Kirk in the Hills boilers 1 & 2  
 Engineer: \_\_\_\_\_  
 Contractor: Western Mechanical Contractors  
 Prepared By: A. Deal Date: 12/7/12  
 Model: H-2005 Indoor/Outdoor: Indoor

# XTherm™ - Type H

Heating Boilers  
 Models 1005-2005

- 96% Thermal Efficiency at Full Rate; Up to 99% at Part Load
- 100% Factory Fire Tested
- Maximum Outlet Water Temperature: 225°F
- Minimum Acceptable Inlet Water Temperature: 50°F
- Full Safety Diagnostics with History
- Footprint: Less Than 10.8 ft<sup>2</sup>
- Limited Twenty-Five-Year Thermal Shock Warranty
- Limited Ten-Year Primary Heat Exchanger Warranty
- Limited Five-Year Secondary Heat Exchanger Warranty
- Full Electronic Modulation, Constant Ratio 4:1 Turndown
- Modulating Controller with LCD Display
- Status Display Lights



### Heat Exchanger

- Headers
  - Cast Iron – Standard
  - Bronze – Option A-1
- ASME H Stamped; 160 PSIG MAWP
- National Board Listed
- Fin Tubing
  - Copper – Standard
  - Cupro Nickel – Option A-3
- ASME Powder-Coated Tube Sheet
- Silicone High Temp O-Rings
- ASME Pressure Relief Valve
  - 60 PSIG – Standard
  - 75 PSIG – Optional
- 150 PSI Air Vent, Auto
- T&P Gauge, Shipped Loose
- Stainless Steel Secondary Heat Exchanger
- Stainless Steel Evaporator Plate
- Boiler Pump: 120V, 1Ø, 60Hz;
  - Cast Iron – Standard
  - Bronze – Option

### Control

- 120V, 60Hz, 1Ø, Power Supply
- 120/24V 60Hz Transformer
- Ignition Module
  - 3-Try – Standard
  - Single-Try – Option C-6
- Hot Surface Ignition (HSI)
- Remote Flame Sensor
- Fixed High Limit, Manual Reset, 240°F
- On/Off Power Switch
- Flow Switch
- Blocked Vent Pressure Switch
- Combustion Air Proving Switch
- Freeze Protection

### Control (cont.)

- Pump Switch
- Pump Time Delay
- Diagnostics Panel with LCD Display, 2 lines, 20 characters
- Modulating Temperature Control
- Water Temperature Sensors (3)
- Cold Water Protection
- Blocked Condensate Switch

### Burner

- Ultra-Low NOx: Less than 20 PPM (Natural Gas Only)

### Gas Train

- Fuel
  - Natural Gas
  - Propane
- Zero Governor Regulator
- Dual-Seat Combination Valve
- Electronic Modulating Firing Mode (H7)

### Construction

- Indoor/Outdoor Construction
- Enclosed Front Controls
- PolyTuf Powder Coat Finish
- Rear Connections (Water, Gas, Vent, Electrical, Comb. Air, Cond. Drain)
- Combustion Air Filter
- Design Certified ANSI Z21.13/CSA 4.9

### Venting

- Vent Termination
  - Outdoor or Indoor, Vertical – Option D-11
  - Indoor, Horizontal – Option D-15
- Extractor - Optional
  - By others
  - Not required

### Multi-Boiler Digital Temp Controllers

- B-36 TempTracker Mod+, 2-4 Boilers, OA Reset
- B-37 TempTracker Mod+, 5-10 Boilers, OA Reset
- B-38 TempTracker Mod+, 11-16 Boilers, OA Reset
- B-45 Multi-Mod Platinum, 2-4 Boilers, OA Reset
- B-46 Multi-Mod Platinum EMS, 2-4 Boilers, OA Reset
- B-47 Multi-Mod Platinum BACNet, 2-4 Boilers, OA Reset
- B-48 Multi-Mod Expansion Module, 1-8 Additional Boilers

### Options

- D-32 PVC Vent Adapter (Includes 200°F Manual High Limit) Maximum return water temperature allowed 170°F. Low Water Cut-Off, Remote Probe
- F-10 High Limit, Auto Reset, Adj., 100-240°F
- I-1 High Limit, Manual Reset, Adj., 100-240°F
- I-2 Low Gas Pressure Switch, Manual Reset
- S-1 High Gas Pressure Switch, Manual Reset
- S-2 Low Gas Pressure Switch, Manual Reset
- Z-12 Condensate Neutralizer Kit

### Regulatory Agency Requirements

- CSD-1



**Rayspak**  
 A Rheem® Company


# XTherm – Type H Models 1005-2005

## Model H-2005


### CLEARANCES (in.)

	Front	Rear	Right	Left	Top	Floor	Vent
<b>Certified Minimum</b>	24	12	1	1	0	0	1
<b>Minimum Service</b>	24	36	24	1	10	N/A	N/A


NOTE: Primary/Secondary plumbing is mandatory for proper operation.



**TOP VIEW**



**FRONT VIEW**



**REAR VIEW**

Model (H7-)	MBTUH		Dimensions (in.)												Ship Weight (Lbs.)	Total Amps**
	Input	Output	B Height	D	E	F	G* NPT	K Flue Ø	L	M	N C/A Ø	P	R	Y		
1005	999	959	55-1/8	45	47-1/8	36-1/2	1-1/4	6	40-1/16	11-1/2	6	47-1/8	8-1/16	6-1/16	1065	22
1505	1500	1440	67-1/8	57	59-1/16	38-1/2	1-1/4	8	52-1/16	12-5/8	8	59-1/8	8-3/16	6-1/16	1234	26
2005	1999	1919	81-1/8	71	71-3/16	38-1/2	2	8	64-1/16	12-5/8	8	73-1/8	8-3/16	6-1/4	1461	35

Note: Ratings shown are for elevations up to 4,500 feet. For installations at elevations above 4,500 feet, please consult the factory for additional instructions.

\* For Propane Gas, all models are 1

\*\* Supply breaker must have delayed trip.

Model (H7-)	Rate of Flow (GPM)			Maximum Flow		Minimum Flow*		Boiler Pump	
	20°F □	30°F □	40°F □*	GPM	□ (°F)	GPM	□ (°F)	Hp	Amps
1005	95	63	47	113	17	47	40	1/2	7
1505	N/A	96	71	113	25	71	40	3/4	11
2005	N/A	N/A	95	116	33	95	40	1	14


\* Closed systems only

Job: Kirk in the Hills boiler 3  
 Engineer: \_\_\_\_\_  
 Contractor: Western Mechanical Contractors  
 Prepared By: A. Deal Date: 12/7/12  
 Model: H-1505 Indoor/Outdoor: Indoor

# XTherm™ - Type H

Heating Boilers  
 Models 1005-2005

- 96% Thermal Efficiency at Full Rate; Up to 99% at Part Load
- 100% Factory Fire Tested
- Maximum Outlet Water Temperature: 225°F
- Minimum Acceptable Inlet Water Temperature: 50°F
- Full Safety Diagnostics with History
- Footprint: Less Than 10.8 ft<sup>2</sup>
- Limited Twenty-Five-Year Thermal Shock Warranty
- Limited Ten-Year Primary Heat Exchanger Warranty
- Limited Five-Year Secondary Heat Exchanger Warranty
- Full Electronic Modulation, Constant Ratio 4:1 Turndown
- Modulating Controller with LCD Display
- Status Display Lights



### Heat Exchanger

- Headers
  - Cast Iron – Standard
  - Bronze – Option A-1
- ASME H Stamped; 160 PSIG MAWP
- National Board Listed
- Fin Tubing
  - Copper – Standard
  - Cupro Nickel – Option A-3
- ASME Powder-Coated Tube Sheet
- Silicone High Temp O-Rings
- ASME Pressure Relief Valve
  - 60 PSIG – Standard
  - 75 PSIG – Optional
- 150 PSI Air Vent, Auto
- T&P Gauge, Shipped Loose
- Stainless Steel Secondary Heat Exchanger
- Stainless Steel Evaporator Plate
- Boiler Pump: 120V, 1Ø, 60Hz;
  - Cast Iron – Standard
  - Bronze – Option

### Control

- 120V, 60Hz, 1Ø, Power Supply
- 120/24V 60Hz Transformer
- Ignition Module
  - 3-Try – Standard
  - Single-Try – Option C-6
- Hot Surface Ignition (HSI)
- Remote Flame Sensor
- Fixed High Limit, Manual Reset, 240°F
- On/Off Power Switch
- Flow Switch
- Blocked Vent Pressure Switch
- Combustion Air Proving Switch
- Freeze Protection

### Control (cont.)

- Pump Switch
- Pump Time Delay
- Diagnostics Panel with LCD Display, 2 lines, 20 characters
- Modulating Temperature Control
- Water Temperature Sensors (3)
- Cold Water Protection
- Blocked Condensate Switch

### Burner

- Ultra-Low NOx: Less than 20 PPM (Natural Gas Only)

### Gas Train

- Fuel
  - Natural Gas
  - Propane
- Zero Governor Regulator
- Dual-Seat Combination Valve
- Electronic Modulating Firing Mode (H7)

### Construction

- Indoor/Outdoor Construction
- Enclosed Front Controls
- PolyTuf Powder Coat Finish
- Rear Connections (Water, Gas, Vent, Electrical, Comb. Air, Cond. Drain)
- Combustion Air Filter
- Design Certified ANSI Z21.13/CSA 4.9

### Venting

- Vent Termination
  - Outdoor or Indoor, Vertical – Option D-11
  - Indoor, Horizontal – Option D-15
- Extractor - Optional
  - By others
  - Not required

### Multi-Boiler Digital Temp Controllers

- B-36 TempTracker Mod+, 2-4 Boilers, OA Reset
- B-37 TempTracker Mod+, 5-10 Boilers, OA Reset
- B-38 TempTracker Mod+, 11-16 Boilers, OA Reset
- B-45 Multi-Mod Platinum, 2-4 Boilers, OA Reset
- B-46 Multi-Mod Platinum EMS, 2-4 Boilers, OA Reset
- B-47 Multi-Mod Platinum BACNet, 2-4 Boilers, OA Reset
- B-48 Multi-Mod Expansion Module, 1-8 Additional Boilers

### Options

- D-32 PVC Vent Adapter (Includes 200°F Manual High Limit) Maximum return water temperature allowed 170°F. Low Water Cut-Off, Remote Probe
- F-10 High Limit, Auto Reset, Adj., 100-240°F
- I-1 High Limit, Manual Reset, Adj., 100-240°F
- I-2 Low Gas Pressure Switch, Manual Reset
- S-1 High Gas Pressure Switch, Manual Reset
- S-2 Low Gas Pressure Switch, Manual Reset
- Z-12 Condensate Neutralizer Kit

### Regulatory Agency Requirements

- CSD-1



**Raupak**  
 A Rheem® Company


# XTherm – Type H Models 1005-2005

## Model H-1505


### CLEARANCES (in.)

	Front	Rear	Right	Left	Top	Floor	Vent
<b>Certified Minimum</b>	24	12	1	1	0	0	1
<b>Minimum Service</b>	24	36	24	1	10	N/A	N/A


NOTE: Primary/Secondary plumbing is mandatory for proper operation.



**TOP VIEW**



**FRONT VIEW**



**REAR VIEW**

Model (H7-)	MBTUH		Dimensions (in.)												Ship Weight (Lbs.)	Total Amps**
	Input	Output	B Height	D	E	F	G* NPT	K Flue Ø	L	M	N C/A Ø	P	R	Y		
1005	999	959	55-1/8	45	47-1/8	36-1/2	1-1/4	6	40-1/16	11-1/2	6	47-1/8	8-1/16	6-1/16	1065	22
1505	1500	1440	67-1/8	57	59-1/16	38-1/2	1-1/4	8	52-1/16	12-5/8	8	59-1/8	8-3/16	6-1/16	1234	26
2005	1999	1919	81-1/8	71	71-3/16	38-1/2	2	8	64-1/16	12-5/8	8	73-1/8	8-3/16	6-1/4	1461	35

Note: Ratings shown are for elevations up to 4,500 feet. For installations at elevations above 4,500 feet, please consult the factory for additional instructions.

\* For Propane Gas, all models are 1

\*\* Supply breaker must have delayed trip.

Model (H7-)	Rate of Flow (GPM)			Maximum Flow		Minimum Flow*		Boiler Pump	
	20°F □	30°F □	40°F □*	GPM	□ (°F)	GPM	□ (°F)	Hp	Amps
1005	95	63	47	113	17	47	40	1/2	7
1505	N/A	96	71	113	25	71	40	3/4	11
2005	N/A	N/A	95	116	33	95	40	1	14

\* Closed systems only

# Raypak X-Therm Start-Up Form

Job Name <b>Kirk in the Hills</b>	Job Location <b>1340 W. Long Lake RD Bloomfield hills, MI</b>	Date <b>6-21-13</b>
--------------------------------------	--	------------------------

Installer <b>western Mech</b>	Contact Person <b>John Hamby</b>	Phone Number <b>586-854-6198</b>
----------------------------------	-------------------------------------	-------------------------------------

Start-up Contractor <b>P.E.G.</b>	Contact Person <b>Scott S</b>	Phone Number <b>734-266-5300</b>
--------------------------------------	----------------------------------	-------------------------------------

Equipment Manufacturer <b>Ray Pak</b>	Model Number <b>H7-2005</b>	Serial Number <b>1212350084</b>	Boiler Control Type <b>TPC</b>	Application of Boiler <b>HTG</b>
--	--------------------------------	------------------------------------	-----------------------------------	-------------------------------------

Condition of Equipment / Installation <b>OK</b>	What Type of Environment is Equipment In? <b>Boiler Room</b>	Is the Equipment Serviceable? <b>Yes</b>
--	---	---

Voltage Test Hot to neutral   <b>123.8</b>   Hot to Ground   <b>123.9</b>   Neutral to Ground   <b>53 mv</b>
---

Make-up Air Size Available <b>Common Duct</b>	Location <b>wall</b>	Are motorized dampers present? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Has an end switch been installed? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
--	-------------------------	---	--

CONTROL SETTINGS Auto Reset High Limit <b>220</b>	Manual Reset High Limit <b>240</b>	Tankstat Setpoint <b>NA</b>	Heating Control Setpoint <b>TPC</b>
--	------------------------------------	-----------------------------	-------------------------------------

GAS TYPE Nat <input checked="" type="checkbox"/> LP <input type="checkbox"/>	PRESSURE RELIEF VALVE PSI <b>60</b> Drip Leg Installed <b>yes</b>	System Working Pressure <b>40</b>	BOILER OPERATION Light <input type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input checked="" type="checkbox"/> Sudden Loads <input type="checkbox"/>
---	--	-----------------------------------	--

PRESSURE SETTINGS: Nat 10.5" max, Pro 13.0" max Supply Gas (Static) <b>10.4</b> w.c. Mfg's Spec <b>&gt;4</b> min w.c.	Manifold Pressure <b>7.85</b> w.c. Mfg's Spec <b>+/- 2</b> w.c.	Blower Tracking Pressure <b>7.51</b> w.c.
Supply Gas (Dynamic) <b>8.0</b> w.c. Mfg's Spec <b>yes</b>	Blower Fan Pressure <b>-4.45</b> w.c. Mfg's Spec <b>7.60</b> Amps in Fee	

SAFETY CONTROL TESTS (Check all that apply & NOTE SETTING)	Flow Switch <input checked="" type="checkbox"/>	Ignition Control Lockout <input checked="" type="checkbox"/>	Auto High Limit <input checked="" type="checkbox"/>	Manual Reset High Limit <input checked="" type="checkbox"/>	Low Gas Pressure Switch <input checked="" type="checkbox"/>	High Gas Pressure Switch <input checked="" type="checkbox"/>
--	---	--	---	---	---	--

VENTING Type <b>metal Fab</b>	Draft Inducer Model # <b>NA</b>	If Used, Approximate Height <b>23' + Elbows</b>	Is Vent Pipe Reduced Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Size <b>8"</b>
Is the boiler gas train vented properly? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		What is the location of the vent termination? <b>wall</b>		Type of Vent Cap <b>angle cut</b>

BOILER TEMPERATURE RISE ΔT at Full Fire <b>29</b>	Comments: <b>Draft Reading -0.048 (-.03 to -.09)</b>
--	--

Does condensate line have neutralizer? Yes  No  Has condensate line off of secondary heat exchanger been run to drain? Yes  No

EMISSION: (Analyzer readings) CO <sub>2</sub> <b>8.8</b> % Mfg's Spec <b>8.5-9.0 (N) 9.5-10.0 (P)</b> %	CO <b>50</b> PPM Mfg's Spec <b>Less 100</b> PPM	Excess Air <b>33</b> % Mfg's Spec _____ %	O <sub>2</sub> <b>5.3</b> % Mfg's Spec _____ %
NO <sub>x</sub> _____ PPM Mfg's Spec _____ PPM	Flue Temperature <b>114</b> °F Mfg's Spec _____ °F		

BOILER PUMP Manufacturer _____ HP _____ Amp Draw <b>13.2</b>	Location <b>Inlet</b>	Outlet _____
Model _____ Voltage <b>110</b> Mfg. Amp Spec <b>14.0</b>	<b>1Phase</b> 3Phase _____	

INJECTION PUMP Manufacturer _____ HP _____ Amp Draw _____	Location _____	Inlet _____	Outlet _____
Model _____ Voltage _____ Mfg. Amp Spec _____	<b>1Phase</b> 3Phase _____		

SYSTEM PUMP Manufacturer _____ HP _____ Amp Draw _____	Location _____	Inlet _____	Outlet _____
Model _____ Voltage _____ Mfg. Amp Spec _____	<b>1Phase</b> 3Phase _____		

MISCELLANEOUS  
Was a service manual present on the job site? Yes  No  Was an owner representative present on startup? Yes  No  Name \_\_\_\_\_

Temp-tracker Settings Mode **8** Blr Target \_\_\_\_\_ DHW Target \_\_\_\_\_ DHW Diff \_\_\_\_\_ Blr Max \_\_\_\_\_ Blr Min \_\_\_\_\_ Dly  3:00 Mass **1**  
Diff \_\_\_\_\_ Mod Dly \_\_\_\_\_ Pump Dly **3:00** Degree **(F°)**

This equipment has been properly started and is operating satisfactorily at this time. Yes  No


Technician's Signature X **Scott Hawere** Date **6-21-13** Owner/Rep's Signature X \_\_\_\_\_ Date \_\_\_\_\_

B-1

# Performance Engineering Group Raypak X-Therm Start-Up Form

## HOW IS BOILER VENTED?

PLEASE SKETCH BOILER'S INSTALLED VENTING SYSTEM. ALSO, DOCUMENT VENT SIZE, VENT LENGTH INCLUDING ALL 45'S AND 90'S.  
PLEASE NOTE ALL TERMINATION POINTS WITH CLEARANCES (INTAKE FROM EXHAUST, AND ALL OTHER CODE/MFG REQUIREMENTS).



Comments:

PLEASE NOTE ANYTHING & EVERYTHING WHICH DOES NOT MEET MANUFACTURER'S SPECIFICATIONS:

Issue with flow from new pumps? Turned off New Section and  
ran old Section pumps OK Now, gas pressure at High End with  
regulator turned all the way down. vent terminations? Bird screen is in

Technician Scott Stevens Date 6-21-13 Customer Don Mieloff Date \_\_\_\_\_

Start-Up will not be done, IF there is any major issue with Water Flow, Gas Supply or Venting

B-2

# Performance Engineering Group

Priority S1 P1 P2 P3

## Raypak X-Therm Start-Up Form


Job Name <b>Kirk in the Hills</b>		Job Location <b>1340 W. Long Lake RD Bloomfield hills, MI</b>		Date <b>6-21-13</b>	
Installer <b>western Mech</b>		Contact Person <b>John Hamby</b>		Phone Number <b>586-854-6198</b>	
Start-up Contractor <b>P.E.G.</b>		Contact Person <b>Scott S</b>		Phone Number <b>734-266-5300</b>	
Equipment Manufacturer <b>Ray Pak</b>	Model Number <b>H7-2005</b>	Serial Number <b>1212350085</b>	Boiler Control Type <b>TPC</b>	Application of Boiler <b>HTG</b>	
Condition of Equipment / Installation <b>OK</b>		What Type of Environment is Equipment In? <b>Boiler Room</b>		Is the Equipment Serviceable? <b>yes</b>	
Voltage Test Hot to neutral   <b>123.8</b>   Hot to Ground   <b>123.8</b>   Neutral to Ground   <b>36mv</b>					
Make-up Air Size Available <b>Ducted (Common)</b>		Location <b>Wall</b>		Are motorized dampers present? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Mfg's Specs		Are Mfg's Specs met? Yes <input type="checkbox"/> No <input type="checkbox"/>		Has an end switch been installed? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
CONTROL SETTINGS Auto Reset High Limit <b>220</b>		Manual Reset High Limit <b>240</b>		Heating Control Setpoint <b>TPC</b>	
GAS TYPE Nat <input checked="" type="checkbox"/> LP <input type="checkbox"/> Other		PRESSURE RELIEF VALVE PSI <b>60</b> Drip Leg Installed <b>yes</b>		BOILER OPERATION Light <input type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input checked="" type="checkbox"/> Sudden Loads <input type="checkbox"/>	
PRESSURE SETTINGS: Nat 10.5" max, Pro 13.0" max					
Supply Gas (Static) <b>0.5</b> w.c.		Mfg's Spec <b>&gt;4" min</b> w.c.		Blower Tracking Pressure <b>2.57</b> w.c.	
Supply Gas (Dynamic) <b>9.1</b> w.c.		Mfg's Spec <b>Y</b>		Mfg's Spec Blower Amps <b>7.58</b> Amps @ 115V	
SAFETY CONTROL TESTS (Check all that apply & NOTE SETTING)					
Flow Switch <input checked="" type="checkbox"/>	Ignition Control Lockout <input checked="" type="checkbox"/>	Auto High Limit <input checked="" type="checkbox"/>	Manual Reset High Limit <input checked="" type="checkbox"/>	Low Gas Pressure Switch <input checked="" type="checkbox"/>	High Gas Pressure Switch <input checked="" type="checkbox"/>
VENTING Type <b>Metal Fab</b> Draft Inducer Model # <b>NA</b>		If Used, Approximate Height <b>23' + Elbows</b>		Is Vent Pipe Reduced? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Size <b>8"</b>	
Is the boiler gas train vented properly? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		What is the location of the vent termination? <b>Wall</b>		Type of Vent Cap <b>Angle cut</b>	
BOILER TEMPERATURE RISE ΔT at Full Fire <b>28</b> Comments:   Draft Reading <b>0.4</b> (-.03 to -.09)					
Does condensate line have neutralizer? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Has condensate line off of secondary heat exchanger been run to drain? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>					
EMISSION: (Analyzer readings)					
CO <sub>2</sub> <b>9.0</b> %		Mfg's Spec <b>8.5-9.0 (N)</b> %		CO <b>54</b> PPM	
Excess Air <b>31</b> %		Mfg's Spec <b>9.5-10.0 (P)</b> %		O <sub>2</sub> <b>5.0</b> %	
NO <sub>x</sub> _____ PPM		Mfg's Spec _____ PPM		Flue Temperature <b>111</b> °F	
BOILER PUMP					
Manufacturer _____		HP _____		Amp Draw <b>13.19</b>	
Model _____		Voltage <b>110</b>		Mfg. Amp Spec <b>14.0</b>	
				Location <b>Inlet</b> Outlet _____	
				1Phase <input checked="" type="checkbox"/> 3Phase _____	
INJECTION PUMP					
Manufacturer _____		HP _____		Amp Draw _____	
Model _____		Voltage _____		Mfg. Amp Spec _____	
				Location _____ Inlet _____ Outlet _____	
				1Phase _____ 3Phase _____	
SYSTEM PUMP					
Manufacturer _____		HP _____		Amp Draw _____	
Model _____		Voltage _____		Mfg. Amp Spec _____	
				Location _____ Inlet _____ Outlet _____	
				1Phase _____ 3Phase _____	
MISCELLANEOUS					
Was a service manual present on the job site? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Was an owner representative present on startup? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Name _____					
Temp-tracker Settings Mode <b>8</b> Blr Target _____ DHW Target _____ DHW Diff _____ Blr Max _____ Blr Min _____ Dly <b>0.00</b> Mass <b>1</b>					
Diff _____ Mod Dly _____ Pump Dly <b>3:00</b> Degree <b>(F)</b>					
This equipment has been properly started and is operating satisfactorily at this time. Yes <input type="checkbox"/> No <input type="checkbox"/>					
Technician's Signature X _____		Date _____		Owner/Rep's Signature X _____	
				Date _____	

B-2

# Performance Engineering Group Raypak X-Therm Start-Up Form

## HOW IS BOILER VENTED?

PLEASE SKETCH BOILER'S INSTALLED VENTING SYSTEM. ALSO, DOCUMENT VENT SIZE, VENT LENGTH INCLUDING ALL 45'S AND 90'S.  
PLEASE NOTE ALL TERMINATION POINTS WITH CLEARANCES (INTAKE FROM EXHAUST, AND ALL OTHER CODE/MFG REQUIREMENTS).



CA  
SEE B-1

### Comments:

PLEASE NOTE ANYTHING & EVERYTHING WHICH DOES NOT MEET MANUFACTURER'S SPECIFICATIONS:

gas pressure at High end with reg backed all the way out.  
advised that spring should be changed to get lower than 10"wc

Technician Scott Stevens Date 6-21-13 Customer Sean Mitchell Date \_\_\_\_\_

Start-Up will not be done, IF there is any major issue with Water Flow, Gas Supply or Venting.



TPI709

Date : 21/06/13  
Time : 07:28

Fuel : Natural Gas

----- Report -----

CO(ppm) : 54  
O2(%) : 5.0  
CO2(%) : 9.0  
Ratio(CO/CO2) : 0.0006  
CO Air Free(ppm) : 70  
Excess Air(%) : 31  
Net\_Effi(%) : 99.4  
Temp\_CH1(F) : 111  
Temp\_CH2(F) : Open

Smoke : 1 2 3 4 5

Customer : Kirk in the Hills

Address :

B-2

Reading Accepted by :

-----  
07:29, 21/06/13

TPI709

Date : 21/06/13  
Time : 06:56

Fuel : Natural Gas

----- Report -----

CO(ppm) : 50  
O2(%) : 5.3  
CO2(%) : 8.8  
Ratio(CO/CO2) : 0.0005  
CO Air Free(ppm) : 67  
Excess Air(%) : 33  
Net\_Effi(%) : 99.3  
Temp\_CH1(F) : 114  
Temp\_CH2(F) : Open

Smoke : 1 2 3 4 5

Customer : Kirk in The Hills

Address : B-1

Reading Accepted by :

-----  
06:57, 21/06/13

TPI709

Date : 21/06/13  
Time : 09:52

Fuel : Natural Gas

----- Report -----

CO(ppm) : 46  
O2(%) : 5.5  
CO2(%) : 8.7  
Ratio(CO/CO2) : 0.0005  
CO Air Free(ppm) : 62  
Excess Air(%) : 35  
Net\_Effi(%) : 98.6  
Temp\_CH1(F) : 138  
Temp\_CH2(F) : Open

Smoke : 1 2 3 4 5

Customer : Kirk in The Hills

Address :

B-3

Reading Accepted by :

-----  
09:53, 21/06/13



Raypak • Ruud • thaw:PAK  
Your Hot Water Supply Resource

June 25, 2013

Mr. John Hamby  
Western Mechanical Contractors  
jhamby@westernmech.com

Dear Mr. Hamby,

The start-up of the Raypak boilers and control system at the following location has been completed:

Kirk in the Hills Church – 1340 W. Long Lake Road – Bloomfield Hills, MI 48302

Model Number: H7-2005  
Serial Number: 1212350084 & 1212350085

The following areas were tested and reviewed:

**Boiler installation**

**Venting**

- Complies with manufacturer’s installation instructions
- Requires the following modifications:
  - Too small; required size is \_\_\_\_\_ inches
  - Exceeds recommended length; correct size for this length is \_\_\_\_\_ inches
  - Exceeds allowable number of elbows; maximum amount is \_\_\_\_\_
  - Requires Barometric Damper
  - Improper vent termination
  - Requires inducer/extractor
  - Other: Engineered Venting System by Partlan-Labodie.

**Make-up Air**

- Complies with manufacturer’s installation instructions
- Requires the following modifications:
  - Undersized; the minimum required size is \_\_\_\_\_
  - Damper interlock not functioning
  - Obstructed inlet
  - Other: FYI: Direct Vent Fresh Air to a Common Box Assembly

**Gas Piping/Pressure**

- Complies with manufacturer’s installation instructions
- Requires the following modifications:
  - Gas pipe undersized; the minimum required size is \_\_\_\_\_
  - Gas pressure too low; the minimum pressure is \_\_\_\_\_
  - Gas pressure too high, the maximum pressure is \_\_\_\_\_
  - Gas vent lines not terminated outside building
  - Gas vent lines too small; correct size should be \_\_\_\_\_
  - Gas vent line/bleed lines combined – not allowed by fuel gas code
  - Other: FYI: Pressure a little high to start. Spring corrected and adjusted.

**Water Piping/Pumping**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Pipe size too small; proper pipe size is
  - Improper pump location; relocate to
  - Improper piping arrangement; see attached drawing
  - Other:

**Equipment Access**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Improper clearance to combustibles
  - Improper service access; minimum access required is            inches
    - Front     Right side     Left Side     Rear
  - Other:

**Electrical**


- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Inadequate voltage supply, proper voltage is
  - Improper ground
  - Inadequate circuit size, minimum circuit is            amps
  - Other:

**Controls**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Improper sensor location
  - Improper sensor wire used; correct wire is
  - Other: FYI: TPC Control System

Enclosed you will find a copy of the startup form. Please forward a copy to the owner/engineer as required.

Respectfully,



James I. Turnquist  
Performance Engineering Group, Inc.

# Performance Engineering Group

Priority S1 P1 P2 P3

## Raypak X-Therm Start-Up Form B-3


Job Name <b>Kirk in the Hills</b>		Job Location <b>1340 W. Long Lake RD Bloomfield hills, MI</b>		Date <b>6-21-13</b>	
Installer <b>Western Mech</b>		Contact Person <b>John Hamby</b>		Phone Number <b>586-854-6198</b>	
Start-up Contractor <b>P.E.G.</b>		Contact Person <b>Scott S</b>		Phone Number <b>734-266-5300</b>	
Equipment Manufacturer <b>Raypak</b>	Model Number <b>H7-1505</b>	Serial Number <b>12 12 350083</b>	Boiler Control Type <b>TPC</b>	Application of Boiler <b>HTG</b>	
Condition of Equipment / Installation <b>OK</b>		What Type of Environment is Equipment In? <b>Boiler Room</b>		Is the Equipment Serviceable? <b>YES</b>	
Voltage Test Hot to neutral <b>123</b>		Hot to Ground <b>123</b>		Neutral to Ground <b>49mV</b>	
Make-up Air Size Available <b>Common Ducted</b>		Location <b>wall</b>		Are motorized dampers present? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Mfg's Specs		Are Mfg's Specs met? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Has an end switch been installed? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
CONTROL SETTINGS Auto Reset High Limit <b>220</b>		Manual Reset High Limit <b>240</b>		Tankstat Setpoint <b>NA</b>	
Heating Control Setpoint <b>TPC</b>		GAS TYPE Nat <input checked="" type="checkbox"/> LP <input type="checkbox"/> Other <input type="checkbox"/>		PRESSURE RELIEF VALVE PSI <b>60</b> Drip Leg Installed <b>yes</b>	
System Working Pressure <b>40</b>		BOILER OPERATION Light <input type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input checked="" type="checkbox"/> Sudden Loads <input type="checkbox"/>		Blower Tracking Pressure <b>7.57</b>	
PRESSURE SETTINGS: Nat 10.5" max, Pro 13.0" max					
Supply Gas (Static) <b>9.0</b>		Mfg's Spec <b>&gt;4" min</b>		Manifold Pressure <b>-1.4</b>	
Supply Gas (Dynamic) <b>6.5</b>		Mfg's Spec Dirt Leg <b>yes</b>		Blower Fan Pressure <b>-3.4</b>	
Mfg's Spec Blower Amps <b>4.1</b>		Mfg's Spec Blower Amps <b>4.1</b>		Mfg's Spec Blower Amps <b>4.1</b>	
SAFETY CONTROL TESTS (Check all that apply & NOTE SETTING)					
Flow Switch <input checked="" type="checkbox"/>		Ignition Control Lockout <input checked="" type="checkbox"/>		Auto High Limit <input checked="" type="checkbox"/>	
Manual Reset High Limit <input checked="" type="checkbox"/>		Low Gas Pressure Switch <input checked="" type="checkbox"/>		High Gas Pressure Switch <input checked="" type="checkbox"/>	
VENTING					
Type <b>Metal Fab</b>		Draft Inducer Model # <b>NA</b>		If Used, Approximate Height <b>23' + Elbows</b>	
Is the boiler gas train vented properly? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		What is the location of the vent termination? <b>wall</b>		Is Vent Pipe Reduced? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Type of Vent Cap <b>Angle Cut</b>		Size <b>8"</b>			
BOILER TEMPERATURE RISE					
ΔT at Full Fire <b>26</b>		Comments: <b>Draft Reading -0.48 (-.03 to -.09)</b>			
Does condensate line have neutralizer? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Has condensate line off of secondary heat exchanger been run to drain? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
EMISSION: (Analyzer readings)					
CO <sub>2</sub> <b>8.7</b> %		Mfg's Spec <b>8.5-9.0 (N) 9.5-10.0 (P)</b> %		CO <b>46</b> PPM	
Excess Air <b>35</b> %		Mfg's Spec %		O <sub>2</sub> <b>5.5</b> %	
NO <sub>x</sub> PPM		Mfg's Spec PPM		Flue Temperature <b>138</b> °F	
BOILER PUMP					
Manufacturer		HP		Amp Draw <b>6.63</b>	
Model		Voltage <b>110</b>		Mfg. Amp Spec <b>7.0</b>	
Location		Inlet		Outlet	
		1Phase		3Phase	
INJECTION PUMP					
Manufacturer		HP		Amp Draw	
Model		Voltage		Mfg. Amp Spec	
Location		Inlet		Outlet	
		1Phase		3Phase	
SYSTEM PUMP					
Manufacturer <b>Paco</b>		HP		Amp Draw	
Model		Voltage		Mfg. Amp Spec	
Location		Inlet		Outlet	
		1Phase		3Phase	
MISCELLANEOUS					
Was a service manual present on the job site? Yes <input type="checkbox"/> No <input type="checkbox"/>		Was an owner representative present on startup? Yes <input type="checkbox"/> No <input type="checkbox"/>		Name	
Temp-tracker Settings Mode <b>E</b>		Blr Target		DHW Target	
DHW Diff		Blr Max		Blr Min	
Dly <b>0:00</b>		Mass		Pump Dly <b>3:00</b>	
Degree <b>F</b>					
This equipment has been properly started and is operating satisfactorily at this time. Yes <input type="checkbox"/> No <input type="checkbox"/>					
Technician's Signature X		Date		Owner/Rep's Signature X	

B-3

# Performance Engineering Group Raypak X-Therm Start-Up Form

## HOW IS BOILER VENTED?

PLEASE SKETCH BOILER'S INSTALLED VENTING SYSTEM. ALSO, DOCUMENT VENT SIZE, VENT LENGTH INCLUDING ALL 45'S AND 90'S.  
PLEASE NOTE ALL TERMINATION POINTS WITH CLEARANCES (INTAKE FROM EXHAUST, AND ALL OTHER CODE/MFG REQUIREMENTS).



### Comments:

PLEASE NOTE ANYTHING & EVERYTHING WHICH DOES NOT MEET MANUFACTURER'S SPECIFICATIONS:

gas pressure 13.8 Reg all the way out. will have to  
change out spring. Changed spring and set at 9.0.

Technician Scott Stevens Date 6-21-13 Customer Alan Mischel Date \_\_\_\_\_

Start-Up will not be done, IF there is any major issue with Water Flow, Gas Supply or Venting.

TPI709

Date : 21/06/13  
Time : 07:28

Fuel : Natural Gas

----- Report -----

CO(ppm) : 54  
O2(%) : 5.0  
CO2(%) : 3.0  
Ratio(CO/CO2) : 0.0006  
CO Air Free(ppm) : 70  
Excess Air(%) : 31  
Net\_Effi(%) : 99.4  
Temp\_CH1(F) : 111  
Temp\_CH2(F) : Open

Smoke : 1 2 3 4 5

Customer : *Kirk in the Hills*

Address :

*B-2*

Reading Accepted by :

07:29, 21/06/13

TPI709

Date : 21/06/13  
Time : 06:56

Fuel : Natural Gas

----- Report -----

CO(ppm) : 50  
O2(%) : 5.3  
CO2(%) : 6.8  
Ratio(CO/CO2) : 0.0005  
CO Air Free(ppm) : 67  
Excess Air(%) : 33  
Net\_Effi(%) : 99.3  
Temp\_CH1(F) : 114  
Temp\_CH2(F) : Open

Smoke : 1 2 3 4 5

Customer : *Kirk in The Hills*

Address : *B-1*

Reading Accepted by :

06:57, 21/06/13

TPI709

Date : 21/06/13  
Time : 09:52

Fuel : Natural Gas

----- Report -----

CO(ppm) : 46  
O2(%) : 5.0  
CO2(%) : 8.7  
Ratio(CO/CO2) : 0.0005  
CO Air Free(ppm) : 62  
Excess Air(%) : 35  
Net\_Effi(%) : 98.6  
Temp\_CH1(F) : 138  
Temp\_CH2(F) : Open

Smoke : 1 2 3 4 5

Customer : *Kirk in The Hills*

Address :

*B-3*

Reading Accepted by :

09:53, 21/06/13



Raypak • Ruud • **thaw:PAK**  
Your Hot Water Supply Resource

June 25, 2013

Mr. John Hamby  
Western Mechanical Contractors  
jhamby@westernmech.com

Dear Mr. Hamby,

The start-up of the Raypak boilers and control system at the following location has been completed:

Kirk in the Hills Church – 1340 W. Long Lake Road – Bloomfield Hills, MI 48302

Model Number: H7-1505  
Serial Number: 1212350083

The following areas were tested and reviewed:

**Boiler installation**

**Venting**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Too small; required size is \_\_\_\_\_ inches
  - Exceeds recommended length; correct size for this length is \_\_\_\_\_ inches
  - Exceeds allowable number of elbows; maximum amount is \_\_\_\_\_
  - Requires Barometric Damper
  - Improper vent termination
  - Requires inducer/extractor
  - Other: Engineered Venting System by Partlan-Labodie.

**Make-up Air**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Undersized; the minimum required size is \_\_\_\_\_
  - Damper interlock not functioning
  - Obstructed inlet
  - Other: FYI: Direct Vent Fresh Air to a Common Box Assembly

**Gas Piping/Pressure**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Gas pipe undersized; the minimum required size is \_\_\_\_\_
  - Gas pressure too low; the minimum pressure is \_\_\_\_\_
  - Gas pressure too high, the maximum pressure is \_\_\_\_\_
  - Gas vent lines not terminated outside building
  - Gas vent lines too small; correct size should be \_\_\_\_\_
  - Gas vent line/bleed lines combined – not allowed by fuel gas code
  - Other: FYI: Pressure a little high to start. Spring corrected and adjusted.

32995 Industrial Road • Livonia • Michigan • 48150 • ph 734.266.5300 • fx 734.266.5310

[www.performanceengineering.com](http://www.performanceengineering.com)

**Water Piping/Pumping**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Pipe size too small; proper pipe size is
  - Improper pump location; relocate to
  - Improper piping arrangement; see attached drawing
  - Other:

**Equipment Access**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Improper clearance to combustibles
  - Improper service access; minimum access required is                      inches
    - Front     Right side     Left Side     Rear
  - Other:

**Electrical**


- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Inadequate voltage supply, proper voltage is
  - Improper ground
  - Inadequate circuit size, minimum circuit is                      amps
  - Other:

**Controls**

- Complies with manufacturer's installation instructions
- Requires the following modifications:
  - Improper sensor location
  - Improper sensor wire used; correct wire is
  - Other: FYI: TPC Control System

Enclosed you will find a copy of the startup form. Please forward a copy to the owner/engineer as required.

Respectfully,



James I. Turnquist  
Performance Engineering Group, Inc.