


						1	EVO HW599 Boiler	7
						2	3" Steel Boiler Manifold	2
						3	UPS 43-100 Boiler Pump	7
						4	3" Common Gas Connection	1
						5	208/240VAC Service Disconnect	· ·
						6	10" SS Common Vent Manifold	1
						7	8" SS Common Vent Manifold	1
						8	Ø12"x48" Custom HSS	1
						9	1" Expansion Tank Connection	1
					6	10	3/4" Water Fill Connection	1
			.			11	System Temperature Sensor	1
						12	3"x2 1/2" Suction Diffuser	3
						13	CRE 32-1 System Pump	2
						14	Copper System Piping Manifold	1
	イト	JEr		FN		15	T&P Gauge	6
					an I	16	6" System Supply Connection	1
	──┨┠		Ħ		H	17	6" System Return Connection	1
						Item #	Description	Qty
							Decemption	
Description:	Revision:	Checked/	Revised by:	Revision	Customor	7		
		Apv. by:		Date:	Customer:	1	Hamilton Engineering, Inc. Innovative Hot Water Solutions 800.968.5530 + www.hamiltonengineering.com	
Added System Pumps & Piping, Rotated HSS Supply 90° Rotated Pump Skid 180°, Modified Piping to Match	A B		BPD BPD	6/4/12 6/5/12	PEG	10-100 Million	800.968.5530 • www.hamiltonengineering.com 34000 Autry St. • Livonia, MI 48150 • Ph: 734.419.0200 • Fax: 73	4.419.0209
	C		BPD	8/13/12	Job Name:		Drawing Description:	E.revisitences
Changed Bolers to HWH 599's from HWH 1999's, Changed System Piping to Copper	1 -	1	-·· •		· · · · · · · · · · · · · · · · ·	[trawing Description.	
Changed Bolers to HWH 599's from HWH 1999's, Changed System Piping to Copper Lowered System Supply, Moved Gas Manifold, Seperated The Racks, Added Sht-4	D		BPD	8/16/12	Country Day			
	D		BPD	8/16/12	Country Day			



Description:	Revision:	Checked/ Apv. by:	Revised by:	Revision Date:	Customer:	Hamilton Engineering, Inc.
Added System Pumps & Piping, Rotated HSS Supply 90°	А		BPD	6/4/12	PEG	800.968.5530 • www.hamiltonengineering.com
Rotated Pump Skid 180°, Modified Piping to Match	В		BPD	6/5/12		34000 Autry St. + Livonia, MI 48150 + Ph: 734.419.0200 + Fax: 734.419.0209
Changed Bolers to HWH 599's from HWH 1999's, Changed System Piping to Copper	с		BPD	8/13/12	Job Name:	Drawing Description:
Lowered System Supply, Moved Gas Manifold, Seperated The Racks, Added Sht-4	D		BPD	8/16/12	Country Day	
					Drawn Date: Drawn By: Sheet No. 05/30/12 B.Donohue 3 of	4 Dwg No. 6524 Scale: Reference dimensions are ± 10%

