MAGNA3

Installation and operating instructions







be think innovate

Original installation and operating instructions.

CONTENTS

		Page
1.	Limited warranty	3
2.	Symbols used in this document	3
3.	General information	4
3.1	Applications	4
3.2	Pumped liquids	4
3.3	Operating conditions	5
3.4	Frost protection	5
3.5	Non-return valve	5 5
3.7	Nameplate	6
3.8	Radio communication	7
3.9	Tools	7
4.	Mechanical installation	7
4.1	Installing the pump	7
4.2	Positioning	8
4.3	Control box positions	8
4.4	Pump head position	8
4.5 E		9
5. 5.1		10
5.2	Connection to the power supply (models 40-XX	
0.2	50-XX, 65-XX, 80-XX, 100-XX)	11
5.3	Connection to the power supply (models 32-XX)	12
5.4	Connection diagram	13
5.5	Input/output communication	15
5.6	Analog input for external sensor	17
5.7 5.8	Priority of settings	18
5.0 6	First start-up	10
0. 7	Pilst statt-up	19
7. 7.1	Overview of settings	20
9.1 9	Menu overview	20
٥. ٥	Control nanel	21
10		22
10.	"Home" menu	22
12	"Status" menu	22
12.	"Settings" manu	23
13.	Settings menu	23 23
13.2	Operating mode	24
13.3	Control mode	24
13.4	FLOWLIMIT	28
13.5	Automatic Night Setback	28
13.6	Relay outputs	29
13.7	Setpoint influence	29
13.0	General settings	30
10.0		30
14.	Assisted numn setun	34 34
14.2	Setting of date and time	34
14.3	Multi-pump setup	34
14.4	Setup, analog input	34
14.5	Description of control mode	34
14.6	Assisted fault advice	34
14.7	Wireless GENIair	34
14.8	muni-pump runction	34

15.	Selection of control mode	35
16.	Fault finding	37
16.1	Grundfos Eye operating indications	37
16.2	Signalling communication with remote control	37
16.3	Fault finding	38
17.	Sensor	39
17.1	Sensor specifications	39
18.	Accessories	40
18.1	Grundfos GO Remote	40
18.2	Communication	40
18.3	Fitting the CIM module	43
19.	Technical data	44
20.	Disposal	44

Warning



Prior to installation, read these installation and operating instructions. Installation and operation must comply with local regulations and accepted codes of good practice.

Warning



The use of this product requires experience with and knowledge of the product.

Persons with reduced physical, sensory or mental capabilities must not use this product, unless they are under supervision or have been instructed in the use of the product by a person responsible for their safety.

Children must not use or play with this product.

English (US)

1. Limited warranty

Products manufactured by GRUNDFOS PUMPS CORPORATION (Grundfos) are warranted to the original user only to be free of defects in material and workmanship for a period of 24 months from date of installation, but not more than 30 months from date of manufacture. Grundfos' liability under this warranty shall be limited to repairing or replacing at Grundfos' option, without charge, F.O.B. Grundfos' factory or authorized service station, any product of Grundfos' manufacture. Grundfos will not be liable for any costs of removal, installation, transportation, or any other charges which may arise in connection with a warranty claim. Products which are sold but not manufactured by Grundfos are subject to the warranty provided by the manufacturer of said products and not by Grundfos' warranty. Grundfos will not be liable for damage or wear to products caused by abnormal operating conditions, accident, abuse, misuse, unauthorized alteration or repair, or if the product was not installed in accordance with Grundfos' printed installation and operating instructions.

To obtain service under this warranty, the defective product must be returned to the distributor or dealer of Grundfos' products from which it was purchased together with proof of purchase and installation date, failure date, and supporting installation data. Unless otherwise provided, the distributor or dealer will contact Grundfos or an authorized service station for instructions. Any defective product to be returned to Grundfos or a service station must be sent freight prepaid; documentation supporting the warranty claim and/or a Return Material Authorization must be included if so instructed.

GRUNDFOS WILL NOT BE LIABLE FOR ANY INCIDENTAL OR CONSEQUENTIAL DAMAGES, LOSSES, OR EXPENSES ARISING FROM INSTALLATION, USE, OR ANY OTHER CAUSES. THERE ARE NO EXPRESS OR IMPLIED WARRANTIES, INCLUDING MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, WHICH EXTEND BEYOND THOSE WARRANTIES DESCRIBED OR REFERRED TO ABOVE.

Some jurisdictions do not allow the exclusion or limitation of incidental or consequential damages and some jurisdictions do not allow limit actions on how long implied warranties may last. Therefore, the above limitations or exclusions may not apply to you. This warranty gives you specific legal rights and you may also have other rights which vary from jurisdiction to jurisdiction.

2. Symbols used in this document



Warning

If these safety instructions are not observed, it may result in personal injury.

Warning

If these instructions are not observed, it may lead to electric shock with consequent risk of serious personal injury or death.



Warning

The surface of the product may be so hot that it may cause burns or personal injury.



Warning

Risk of dropping objects which may cause personal injury.

Warning Escaping

Escaping vapor involves the risk of personal injury.



If these safety instructions are not observed, it may result in malfunction or damage to the equipment.



Notes or instructions that make the job easier and ensure safe operation.

3. General information



The Grundfos MAGNA3 is a complete range of circulator pumps with integrated controller enabling adjustment of pump performance to the actual system requirements. In many systems, this will reduce the power consumption considerably. reduce noise from thermostatic radiator valves and similar fittings and improve the control of the system.

The desired head can be set on the pump control panel.

3.1 Applications

The Grundfos MAGNA3 is designed for circulating liquids in the following systems:

- heating systems
- domestic hot-water systems
- air-conditioning and cooling systems. •

The pump can also be used in the following systems:

- ground source heat pump systems
- solar-heating systems. •

3.2 Pumped liquids

The pump is suitable for thin, clean, non-aggressive and non-explosive liquids, not containing solid particles or fibers that may attack the pump mechanically or chemically.

In heating systems, the water should meet the requirements of accepted standards on water quality in heating systems.

In domestic hot-water systems, we recommend to use MAGNA3 pumps only for water with a degree of hardness lower than approx. 14 °dH.

In domestic hot-water systems, we recommend to keep the liquid temperature below 150 °F (+65 °C) to eliminate the risk of lime precipitation.



Warning

Do not use the pump for flammable liquids, such as diesel oil and gasoline.



Warning

Do not use the pump for aggressive liquids, such as acids and sea water.



Fig. 1 Pumped liquids

3.2.1 Glycol

The pump can be used for pumping water/glycol mixtures up to 50 %.

Example of a water/ethylene glycol mixture:

Maximum viscosity: 50 cSt ~ 50 % water / 50 % ethylene glycol mixture at +14 °F (-10 °C).

The pump has a power-limiting function that protects against overload.

The pumping of glycol mixtures will affect the max. curve and reduce the performance, depending on the water/ethylene glycol mixture and the liquid temperature.

To prevent the ethylene glycol mixture from degrading, avoid temperatures exceeding the rated liquid temperature and minimize the operating time at high temperatures.

It is important to clean and flush the system before the ethylene glycol mixture is added.

To prevent corrosion or lime precipitation, check and maintain the ethylene glycol mixture regularly. If further dilution of the supplied ethylene glycol is required, follow the glycol supplier's instructions.

Note

Additives with a density and/or kinematic viscosity higher than those/that of water will reduce the hydraulic performance.

3.3 Operating conditions



Fig. 2 Operating conditions

3.3.1 Liquid temperature

See fig. 2, pos. 1.

Continuously: +14 °F to +230 °F (-10 °C to +110 °C).

Domestic hot-water systems:

• Up to +150 °F (+65 °C).

3.3.2 System pressure

See fig. 2, pos. 2.

The maximum permissible system pressure is stated on the pump nameplate.

3.3.3 Ambient temperature

See fig. 2, pos. 3.

+32 °F to +104 °F (0 °C to +40 °C).

The control box is air-cooled. Therefore, it is important that the maximum permissible ambient temperature is not exceeded during operation.

During transport: -40 °F to +158 °F (-40 °C to +70 °C).

3.3.4 Sound pressure level

See fig. 2, pos. 4.

The sound pressure level of the pump is lower than 43 dB(A).

3.3.5 Approvals

- · Conforms to ANSI/UL Standard 778.
- Certified to CAN/CSA Standard C22.2 No. 108.
- The protective earth (ground) symbol
 identifies any
 terminal which is intended for connection to an external
 conductor for protection against electric shock in case of a
 fault, or the terminal of a protective earth (ground) electrode.

3.4 Frost protection

Caution

If the pump is not used during periods of frost, necessary steps must be taken to prevent frost bursts.



Additives with a density and/or kinematic viscosity higher than those/that of water will reduce the hydraulic performance.

3.5 Insulating shells

Insulating shells are available for single-head pumps only.

Note Limit the heat loss from the pump housing and pipework.

The heat loss from the pump and pipework can be reduced by insulating the pump housing and the pipework. See fig. 3 and fig. 13.

- Insulating shells for pumps in heating systems are supplied with the pump; see fig. 3.
- For pumps in air-conditioning and cooling systems (down to +14 ° (-10 °C)) it is required to apply a silicon sealant to the internal contours of the shell in order to eliminate any air gaps and prevent condensation between the insulation shell and pump housing. Alternatively, the pump can also be insulated manually in accordance with standard insulating requirements for heating and cooling systems (fig. 13).

The fitting of insulating shells will increase the pump dimensions.



Fig. 3 Fitting insulating shells to the pump

Caution Do not insulate the control box or cover the control panel.

3.6 Non-return valve

If a non-return valve is fitted in the pipe system (fig. 4), it must be ensured that the set minimum discharge pressure of the pump is always higher than the closing pressure of the valve. This is especially important in proportional-pressure control mode (reduced head at low flow). The closing pressure of a single non-return valve is accounted for in the pump settings as the minimum head delivered is 5 ft (1.5 m).



Fig. 4 Non-return valve

TM05 3055 0912

3.7 Nameplate

The pump nameplate provides the following information:



Fig. 5 Example of nameplate

Pos.	Description
1	Product name
2	Model
3	Production code (year and week)
4	Serial number
5	Product number
6	Enclosure type
7	Energy Efficiency Index (EEI)
8	Part (according to EEI)
9	TF-class
10	Minimum current [A]
11	Maximum current [A]
12	Minimum power [W]
13	Maximum power [W]
14	Maximum pressure
15	Voltage [V] and frequency [Hz]
16	QR (Quick Response) code
17	Approvals (nameplate)
18	Assembled in USA

3.8 Radio communication

The wireless radio in this product is class B.

Intended use

This product incorporates a radio for remote control.

The product can communicate with Grundfos Go Remote and with other MAGNA3 pumps of the same type via the built-in radio. Only Grundfos-approved external antennae may be connected to this product, and only by a Grundfos-approved installer.

3.9 Tools



Fig. 6 Recommended tools

Pos.	ΤοοΙ	Size
1	Screwdriver, straight slot	1.2 x 8.0 mm
2	Screwdriver, straight slot	0.6 x 3.5 mm
3	Screwdriver, torx bit	TX20
4	Hexagon key	5.0 mm
5	Open-end wrench	Depending on flange bolt size
6	Wire cutter	
7	Pipe wrench	

4. Mechanical installation



4.1 Installing the pump

MAGNA3 is designed for indoor installation.

The pump must be installed in such a way that it is not stressed by the pipework.

The pump may be suspended direct in the pipes, provided that the pipework can support the pump.

Twin-head pumps are prepared for installation on a mounting bracket or base plate.

To ensure adequate cooling of motor and electronics, the following must be observed:

- Position the pump in such a way that sufficient cooling is ensured.
- The temperature of the ambient air must not exceed +104 °F (+40 °C).



Warning Observe local regulations setting limits for manual lifting or handling.

Step Action

1Arrows on the pump housing
indicate the liquid flow direction
through the pump. The liquid
flow direction can be horizontal
or vertical, depending on the
control box position.Image: Consection of the pump.2Close the isolating valves and
make sure that the system is not
pressurized during the
installation of the pump.Image: Consection of the pump.3Mount the pump with gaskets in
the pipework.Image: Consection of the pump with gaskets in
the pipework.

Fit bolts and nuts. Use the right size of bolts according to system pressure.



Illustration

TM05 2862 0612

TM05 2863 0612

TM05 2864 061

4.2 Positioning

Always install the pump with horizontal motor shaft.

- Pump installed correctly in a vertical pipe. See fig. 7, pos. A.
- Pump installed correctly in a horizontal pipe. See fig. 7, pos. B.
- Do not install the pump with vertical motor shaft. See fig. 7, pos. C and D.



Fig. 7 Pump installed with horizontal motor shaft

4.3 Control box positions

To ensure adequate cooling, the control box must be in horizontal position with the Grundfos logo in vertical position. See fig. 8.



Fig. 8 Pump with control box in horizontal position

If the pump head is removed before the pump is installed in the pipework, pay special attention when fitting the pump head to the pump housing:

- 1. Gently lower the pump head with rotor shaft and impeller into the pump housing.
- 2. Make sure that the contact face of the pump housing and that of the pump head are in contact before the clamp is tightened. See fig. 9.



Fig. 9 Fitting the pump head to the pump housing

4.4 Pump head position

If the pump head is removed before the pump is installed in the pipework, pay special attention when fitting the pump head to the pump housing:

- 3. Visually check that the floating ring in the sealing system is centered. See figs. 10 and 11.
- 4. Gently lower the pump head with rotor shaft and impeller into the pump housing.
- 5. Make sure that the contact face of the pump housing and that of the pump head are in contact before the clamp is tightened. See fig. 12.



Fig. 10 Correctly centered sealing system



Fig. 11 Incorrectly centered sealing system

Observe the position of the clamp before the clamp is tightened. Incorrect position of the Caution clamp will cause leakage from the pump and damage the hydraulic parts in the pump head. See fig. 12.



Fig. 12 Fitting the pump head to the pump housing

4.5 Changing the control box position

Warning



The warning symbol on the clamp holding the pump head and pump housing together indicates that there is a risk of personal injury. See specific warnings below.

Warning



When loosening the clamp, do not drop the pump head.

Illustration



TM05 6651 5012

TM05 5837 4112

Warning Risk of escaping vapor.

Step Action



Step Action

Illustration

Single-head pump. Note: The gap of the clamp can also be in position 6 o'clock for the following pump sizes:

MAGNA3 65-XX

4b

4d

6

Caution

- MAGNA3 80-XX
- MAGNA3 100-XX.

Twin-head pump. Position the clamps so that the gaps point towards the arrows.

4c They can be in position 3 or 9 o'clock.





Note: The gap of the clamp can also be in position 6 o'clock for the following pump sizes:

- MAGNA3 65-XX
- MAGNA3 80-XX
- MAGNA3 100-XX.

Fit and tighten the screw holding the clamp to minimum 6 ± 0.7 ft-lbs (8 ± 1 Nm).

Fit the insulating shells. Note: For air conditioning and cooling systems a silicone sealant must be applied inside the insulation shell to eliminate all air

gaps and prevent condensation 7 between the pump housing and insulation shell. Alternatively, the pump may be insulated manually in accordance with standard insulation practices for cooling applications.

TM05 2874 0412

If insulating the pump manually, do not insulate the control box or cover the control panel.



Fig. 13 Insulation of pump housing and pipework

5. Electrical installation



Carry out the electrical connection and protection according to local regulations.

Check that the supply voltage and frequency correspond to the values stated on the nameplate.



Warning



Never make any connections in the pump control box unless the power supply has been switched off for at least 5 minutes.

Warning

The pump must be connected to an external mains switch with a contact separation of at least 1/8 inch (3 mm) in each pole.

The ground terminal of the pump must be connected to ground. Grounding or neutralization can be used for protection against indirect contact.

If the pump is connected to an electric installation where a Ground Fault Circuit Interrupter (GFCI) is used as additional protection, this circuit interrupter must trip out when ground fault currents with DC content (pulsating DC) occur.

- If rigid conduit is to be used, the hub must be connected to the conduit system before it is connected to the terminal box of the pump.
- The pump must be connected to an external mains switch.
- The pump requires no external motor protection.
- The motor incorporates thermal protection against slow overloading and blocking.
- When switched on via the power supply, the pump will start pumping after approx. 5 seconds.



TM05 5549 3812

The number of starts and stops via the power supply must not exceed four times per hour.



5.1 Supply voltage

1 x 115 V ± 10 %, 50/60 Hz, PE.

1 x 208-230 V ± 10 %, 50/60 Hz, PE.

See pump nameplate for rated supply voltage

The voltage tolerances are intended for mains voltage variations. They should not be used for running pumps at other voltages than those stated on the nameplate.

5.2 Connection to the power supply (models 40-XX, 50-XX, 65-XX, 80-XX, 100-XX)





English (US)

5.3 Connection to the power supply (models 32-XX)





5.4 Connection diagram



TM03 2397 0312

Fig. 14 Example of typical connection, 1 x 230 V ± 10 %, 50/60 Hz

Note All cables used must be connected in accordance with local regulations.

5.4.1 Connection to external controllers



Fig. 15 Example of connections in the control box



Warning

Wires connected to supply terminals, outputs NC, NO, C and start/stop input must be separated from each other and from the supply by reinforced insulation.

Concerning demands on signal wires and signal transmitters, see section 19. Technical data.

Use screened cables for external on/off switch, digital input, sensor and setpoint signals.



All cables used must be heat-resistant up to +185 °F (+85 °C).



Fig. 16 Wiring diagram, 32-XX versions

The connection terminals of 32-XX versions differ from those of terminal-connected versions, but they have the same function and connection options.

Use screened cables for external on/off switch, digital input, sensor and setpoint signals.

Connect screened cables to the ground connection as follows:

- Terminal-connected versions: Connect the cable screen to ground via the digital-input terminal (earth).
- Plug-connected versions: Connect the cable screen to ground via cable clamp.



Warning

Wires connected to supply terminals, outputs NC, NO, C and start/stop input must be separated from each other and from the supply by reinforced insulation.



All cables used must be heat-resistant up to +85 °C.

All cables used must be installed in accordance with EN 60204-1 and EN 50174-2:2000.

5.5 Input/output communication

- Relay outputs
- Alarm, ready and operating indication via signal relay.
- Digital input
 - Start/Stop (S/S)
 - Min. curve (MI)
 - Max. curve (MA).
- Analog input

0-10 V or 4-20 mA control signal.

To be used for external control of the pump or as sensor input for the control of the external setpoint.

The 24 V supply from pump to sensor is optional and is normally used when an external supply is not available.

5.5.1 Relay outputs

See fig. 15, pos. 1.

The pump incorporates two signal relays with a potential-free changeover contact for external fault indication.

The function of the signal relay can be set to "Alarm", "Ready" or "Operation" on the pump control panel or with Grundfos GO Remote.

The relays can be used for outputs up to 250 V and 2 A.



TM05 3338 1212

Fig. 17 Relay output

Contact symbol	Function
NC	Normally closed
NO	Normally open
С	Common

The functions of the signal relays appear from the table below:

Signal relay	Alarm signal		
1 2 3 NC NO C	Not activated: The power supply has been switched off. The pump has not registered a fault. 		
	Activated: • The pump has registered a fault.		
Signal relay	Ready signal		
1 2 3 NC NO C	Not activated:The pump has registered a fault and is unable to run.		
1 2 3 NC NO C	 Activated: The pump has been set to stop, but is ready to run. The pump is running. 		
Signal relay	Operating signal		
1 2 3 NC NO C	Not activated: • The pump is not running.		
	Activated: • The pump is running.		

5.5.2 Digital inputs

See fig. 15, pos. 2.

The digital input can be used for external control of start/stop or forced max. or min. curve.

If no external on/off switch is connected, the jumper between terminals Start/Stop (S/S) and frame (\perp) should be maintained. This connection is the factory setting.

S/S

External forced max. or min. curve

The pump can be forced to operate on the max. or min. curve via the digital input.



Select the function of the digital input on the pump control panel or with Grundfos GO Remote.



Fig. 18 Digital input

Contact symbol	Function	
М	Max. curve	
A	100 % speed	
М	Min. curve	
I	25 % speed	
S/S	Start/Stop	
L	Frame connection	

External start/stop

The pump can be started or stopped via the digital input.



5.6 Analog input for external sensor

The analog input can be used for the connection of an external sensor for measuring temperature or pressure.

The analog input can also be used for an external signal for the control from a BMS system or similar control system.

The electrical signal for the input can be 0-10 VDC or 4-20 mA. The selection of electrical signal (0-10 V or 4-20 mA) can be changed on the control panel or with Grundfos GO Remote.



Fig. 19 Analog input for external sensor or control

In order to optimize the pump performance, external sensors can advantageously be used in the following cases:

Function/control mode	Sensor type		
Heat energy meter	Temperature sensor		
Constant temperature	Temperature sensor		
Differential pressure	Pressure sensor		



Fig. 20 Wiring, analog input

PIN	Description	Load	
IN	Analog input	150 Ω (4-20 mA signal) 78 kΩ (0-10 V signal)	
24 V	24 V supply to external sensor	Max. 22 mA	

↓ Ground for external sensor



Fig. 21 Examples of external sensors

TM05 3221 1112

Pos.	Sensor type
1	Differential pressure transmitter, Grundfos type DPI V.2 1/2" connection and 4-20 mA signal.
2	Relative pressure transmitter, combined pressure and temperature sensor, Grundfos type RPI/T G 1/2" connection and 4-20 mA signal.

For further details, visit WebCAPS and reference Magna3 Data booklet 98439208.



Fig. 22 Example of external signal for the control via BMS or PLC

5.7 Electrical connection for external sensor



Fig. 23 Example electrical connections for external sensor

PIN	1	2	3	4
Wire color	Brown	Grey	Blue	Black
Output 4 to 20 mA	+	not used	-	not used
Output 2 x 0 to 10 V	+	Pressure signal	_*	Temperature signal

* Common ground for both pressure and temperature signal.

* Power supply (screened cable): SELV or PELV.

5.8 Priority of settings

The external forced-control signals will influence the settings available on the pump control panel or with Grundfos GO Remote. However, the pump can always be set to max. curve duty or to stop on the pump control panel or with Grundfos GO Remote.

If two or more functions are enabled at the same time, the pump will operate according to the setting with the highest priority. The priority of the settings is as shown in the table below.

Example: If the pump has been forced to stop via an external signal, the pump control panel or Grundfos GO Remote can only set the pump to max. curve.

	Р	ossible settings	
Priority	Pump control panel or Grundfos GO Remote	External signals	Bus signal
1	Stop		
2	Max. curve		
3		Stop	
4			Stop
5			Max. curve
6			Min. curve
7			Start
8		Max. curve	
9	Min. curve		
10		Min. curve	
11	Start		

As illustrated in the table, the pump does not react to external signals (max. curve and min. curve) when it is controlled via bus. For further details, please contact Grundfos.

6. First start-up

Do not start the pump until the system has been filled with liquid and vented. Furthermore, the required minimum inlet pressure must be available at the pump inlet. See section *19. Technical data.*

The system cannot be vented through the pump. The pump is self-venting.

Step	Action	Illustration
1	Switch on the power supply to the pump. Note: When switched on, the pump will start in AUTO _{ADAPT} after approx. 5 seconds.	0/Off
2	Pump display at first start-up. After a few seconds, the pump display will change to the start-up guide.	TMOS 2865 0612
3	The start-up guide will guide you through the general settings of the pump, such as language, date and time. If the buttons on the pump control panel are not touched for 15 minutes, the display will go into sleep mode. When a button is touched, the "Home" display will appear.	<image/> <page-header></page-header>
4	When the general settings have been made, select the desired control mode or let the pump run in AUTO _{ADAPT} . For additional settings, see section 7. Settings.	TM05 2887 0612

7. Settings



7.1 Overview of settings

All settings can be made on the pump control panel or with Grundfos GO Remote.

Menu	Submenu	Further information
Setpoint		See section 13.1 Setpoint.
Operating mode		See section 13.2 Operating mode.
	Normal	
	• Stop	
	• Min.	
	• Max.	
Control mode		See section 13.3 Control mode.
	• AUTO _{ADAPT}	See section 13.3.1 AUTOADAPT.
	• FLOW _{ADAPT}	See section 13.3.2 FLOWADAPT.
	Prop. press.	See section 13.3.3 Proportional pressure.
	Const. press.	See section 13.3.4 Constant pressure.
	Const. temp.	See section 13.3.5 Constant temperature.
	Differential temperature	See section 13.3.6 Differential temperature.
	Constant curve	See section 13.3.7 Constant curve.
FLOW _{LIMIT}		See section 13.4 FLOWLIMIT.
	Set FLOWLIMIT	
Automatic Night Setback		See section 13.5 Automatic Night Setback.
	Not active	5
	Active	
Relay outputs	, (611)	See section 13.6 Palay outputs
Nelay outputs		See section 13.0 helay outputs.
	Relay output 1	
	Relay output 2	
Setpoint influence		See section 13.7 Setpoint influence.
	 External setpoint function 	See section 13.7.1 External setpoint function.
	Temperature influence	See section 13.7.2 Temperature influence.
Bus communication		See section 13.8 Bus communication.
	Pump number	See section 13.8.1 Pump number.
General settings		See section 13.9 General settings.
	Language	See section 13.9.1 Language.
	Set date and time	See section 13.9.2 Set date and time.
	• Units	See section 13.9.3 Units.
	Enable/disable settings	See section 13.9.4 Enable/disable settings.
	Delete history	See section 13.9.5 Delete history.
	Define Home display	See section 13.9.6 Define Home display.
	 Display brightness 	See section 13.9.7 Display brightness.
	Return to factory settings	See section 13.9.8 Return to factory settings.
	Run start-up guide	See section 13.9.9 Run start-up guide.

Status Operating status Operating mode, from Control mode Pump performance Max. curve and duty point Resulting setpoint Liquid temperature Speed Operating hours Power and energy consumption Power consumption Energy consumption Warning and alarm Actual warning or alarm Warning log Warning log 1 to 5 Alarm log Alarm log 1 to 5 Heat energy meter Heat power Heat energy Flow rate Volume Hours counter **Temperature 1** Temperature 2 Differential temp. Work log Operating hours Trend data Duty point over time 3D showing (Q, H, t) 3D showing (Q, T, t) 3D showing (Q, P, t) 3D showing (T, P, t) Fitted modules Date and time Date Time Pump identification Multi-pump system Operating status Operating mode, from Control mode System performance Duty point Resulting setpoint System identification Power and energy consumption Power consumption Energy consumption Other pump 1, multi-pump sys.

Settings

Setpoint Operating mode Control mode FLOW_{LIMIT} Enable FLOWLIMIT function Set FLOWLIMIT Automatic Night Setback Relay outputs Relay output 1 Relay output 2 Not active Ready Alarm Operation Setpoint influence External setpoint function Temperature influence Bus communication Pump number General settings Language Set date and time Select date format Set date Select time format Set time Units SI or US units Customized units Pressure Differential pressure Head Level Flow rate Volume Temperature Differential temp. Power Energy Enable/disable settings Delete history Delete work log Delete heat energy data Delete energy consumption Define Home display Select Home display type List of data Graphical illustration Define Home display contents List of data Graphical illustration **Display brightness** Brightness Return to factory settings Run start-up guide

Assist

Assisted pump setup Setting of pump Setting of date and time Date format, date and time Date only Time only Multi-pump setup Setup, analog input Description of control mode AUTO ADAPT FLOW_{ADAPT} Prop. press. Const. press. Const. temp. Differential temperature Constant curve Assisted fault advice Blocked pump Pump communication fault Internal fault Internal sensor fault Dry running Forced pumping Undervoltage Overvoltage External sensor fault

9. Control panel



Warning

At high liquid temperatures, the pump housing may be very hot. In that case, only touch the control panel.



Fig. 24 Control panel

Button	Function
۲	Goes to the "Home" menu.
۲	Returns to the previous action.
< >	Navigates between main menus, displays and digits. When the menu is changed, the display will always show the top display of the new menu.
~ ~	Navigates between submenus.
OK	Saves changed values, resets alarms and expands the value field.

10. Menu structure

The pump incorporates a start-up guide which is started at the first start-up. After the start-up guide, the four main menus will appear in the display. See section *6. First start-up*.

1. Home

This menu shows up to four user-defined parameters with shortcuts or a graphical illustration of a Q/H performance curve. See section *11. "Home" menu.*

2. Status

This menu shows the status of the pump and system as well as warnings and alarms. See section *12. "Status" menu.*



3. Settings

This menu gives access to all setting parameters. A detailed setting of the pump can be made in this menu. See section *13. "Settings" menu.*

4. Assist

This menu enables assisted pump setup, provides a short description of the control modes and offers fault advice. See section *14. "Assist" menu.*

11. "Home" menu



Navigation

Home

Press (a) to go to the "Home" menu.

"Home" menu (factory setting)Shortcut to control mode settings

- Shortcut to setopint settings
- Shortcut to setpoint settings
- Flow rateHead.

Head.

Navigate in the display with \checkmark or \checkmark and change between the two shortcuts with $\mathrel{>}$ or $\mathrel{<}$.

The "Home" display can be defined by the user. See section 13.9.6 Define Home display.

English (US)

3.1.0.0.0.0 Settings

12. "Status" menu



Navigation

Home > Status

Press and go to the "Status" menu with >.

"Status" menu

This menu offers the following status information:

- Operating status
- Pump performance
- Power and energy consumption
- Warning and alarm
- Heat energy meter
- Work log
- Fitted modules
- Date and time
- Pump identification
- Multi-pump system.

Navigate between submenus with \checkmark or \checkmark .

13. "Settings" menu

n Ho Status Settings	Assist
	3.1.0.0.0.0
Setpoint	
Operating mode	
Control mode	
FLOW <i>LIMIT</i>	
Automatic Night Setback	

Navigation

2.1.0.0.0.0 Status

Home > Settings

Press
and go to the "Settings" menu with >.

"Settings" menu

This menu offers the following setting options:

- Setpoint
- Operating mode
- Control mode
- FLOW_{LIMIT}
- Automatic Night Setback
- Relay outputs
- Setpoint influence
- Bus communication
- General settings.

Navigate between submenus with \checkmark or \bigstar .

13.1 Setpoint



TM05 7925 1613

Navigation

Home > Settings > Setpoint

Setpoint

Set the setpoint so that it matches the system. Setting:

- 1. Press [OK] to start the setting.
- 2. Select digit with \triangleleft and \triangleleft and adjust with \checkmark or \triangleleft .
- 3. Press [OK] to save.

A too high setting may result in noise in the system whereas a too low setting may result in insufficient heating or cooling in the system.

Control mode	Measuring unit
Proportional pressure	m, ft
Constant pressure	m, ft
Constant temperature	°C, °F, K
Constant curve	%

English (US)

13.2 Operating mode



Navigation

Home > Settings > Operating mode

Operating mode

- Normal (control mode)
- Stop
- Min. (min. curve)
- Max. (max. curve).

Setting:

- 1. Select operating mode with \checkmark or \blacktriangle .
- 2. Press [OK] to save.

The pump can be set to operate according to the max. or min. curve, like an uncontrolled pump. See fig. 25.



Fig. 25 Max. and min. curves

- Normal: The pump runs according to the selected control mode.
- Stop: The pump stops.
- Min.: The min. curve mode can be used in periods in which a minimum flow is required. This operating mode is for instance suitable for manual night

setback if Automatic Night Setback is not desired.

 Max.: The max. curve mode can be used in periods in which a maximum flow is required.
 This operating mode is for instance suitable for bot-water.

This operating mode is for instance suitable for hot-water priority.

13.3 Control mode



Navigation

3.1.2.0.0.0 Operating mode

Home > Settings > Control mode

Control mode

- AUTO_{ADAPT}
- FLOW_{ADAPT}
- Prop. press. (proportional pressure)
- Const. press. (constant pressure)
- Const. temp.(constant temperature)
- Constant curve.

Note The operating mode must be set to "Normal" before a control mode can be enabled.

Setting:

- 1. Select control mode with \checkmark or \checkmark .
- 2. Press [OK] to enable.

The setpoint for all control modes, except AUTO_{ADAPT} and FLOW_{ADAPT}, can be changed in the "Setpoint" submenu under "Settings" when the desired control mode has been selected.

All control modes, except "Constant curve", can be combined with Automatic Night Setback. See section *13.5 Automatic Night Setback*.

The FLOW_{LIMIT} function can also be combined with the last five control modes mentioned above. See section 13.4 FLOWLIMIT.

13.3.1 AUTO ADAPT

The AUTO_{ADAPT} control mode continuously adapts the pump performance according to the actual system characteristic.





Fig. 26 AUTO_{ADAPT}

When the AUTO_{ADAPT} control mode has been enabled, the pump will start with the factory setting, $H_{fac} = H_{set1}$, corresponding to approx. 55 % of its maximum head, and then adjust its performance to A_1 . See fig. 26.

When the pump registers a lower head on the max. curve, A₂, the AUTO_{ADAPT} function will automatically select a correspondingly lower control curve, H_{set2}. If the valves in the system close, the pump will adjust its performance to A₃.

Δ		Original	duty	noint
A1	•	Unginar	uuty	point.

- A₂: Lower registered head on the max. curve.
- A₃: New duty point after AUTO_{ADAPT} control.
- H_{set1}: Original setpoint setting.
- H_{set2}: New setpoint after AUTO_{ADAPT} control.
- H_{fac.}: MAGNA3 xx-60: 11.4 ft (3.5 m) MAGNA3 xx-80: 14.7 ft (4.5 m) MAGNA3 xx-100: 18 ft (5.5 m) MAGNA3 xx-120: 21.3 ft (6.5 m) MAGNA3 xx-150: 26.2 ft (8.0 m) MAGNA3 xx-180: 31.1 ft (9.5 m).
- H_{auto_min}: A fixed value of 4.9 ft (1.5 m).

The AUTO_{*ADAPT*} control mode is a form of proportional-pressure control where the control curves have a fixed origin, H_{auto_min} . The AUTO_{*ADAPT*} control mode has been developed specifically for heating systems and is not recommended for air-conditioning and cooling systems.

To reset AUTO_{ADAPT}, see section 13.9.8 Return to factory settings.

13.3.2 FLOW_{ADAPT}

When FLOW_{ADAPT} is selected, the pump will run AUTO_{ADAPT} and ensure that the flow never exceeds the entered FLOW_{LIMIT} value. The setting range for the FLOW_{LIMIT} is 25 to 90 % of the Q_{max} of the pump.

The factory setting of the FLOW_{LIMIT} is the flow where the AUTO_{ADAPT} factory setting meets the max. curve. See fig. 27.



Fig. 27 FLOWADAPT

13.3.3 Proportional pressure

The pump head is reduced at decreasing water demand and increased at rising water demand. See fig. 28.





TM05 2448 1212

13.3.4 Constant pressure

The pump maintains a constant pressure, irrespective of water demand. See fig. 29.



Fig. 29 Constant pressure

13.3.5 Constant temperature

This control mode ensures a constant temperature. Constant temperature is a comfort control mode that can be used in domestic hot-water systems to control the flow to maintain a fixed temperature in the system. See fig. 30. When this control mode is used, no balancing valves must be installed in the system.

If the pump is installed in the return pipe of the system, the internal temperature sensor can be used. In this case, the pump must be installed as close as possible to the consumer (radiator, heat exchanger, etc.).

If the pump is installed in the flow pipe, an external temperature sensor must be installed in the return pipe of the system. The sensor must be installed as close as possible to the consumer (radiator, heat exchanger, etc.).

The constant-temperature control mode also reduces the risk of bacterial growth (for example Legionella) in the system. It is possible to set the sensor range:

- It is possible to set the sens
- min. +14 °F (-10 °C)

Note

• max. +266 °F (+130 °C).

To ensure that the pump is able to control, we recommend to set the sensor range between +3 °F and +257 °F (-5 and +125 °C).



Fig. 30 Constant temperature

13.3.6 Differential temperature

This control mode ensures a constant differential temperature drop across a heating system.

The pump should be installed in the flow pipe so the built-in sensor measures the liquid temperature going out to the load. An external temperature sensor must be installed in the system to measure the liquid temperature returning from the heating load. In this mode, the pump will maintain a constant temperature. See figs 31 and 32, differential between the pump and the external sensor.



Fig. 31 Differential temperature



Fig. 32 Differential temperature



Note

TM05 2451 5111

Changing K_p and T_i values are only possible with Grundfos GO.

Changing the K_p and T_i values will affect all control modes. If the control mode is to be changed back to another mode you must set the K_p and T_i values back to default values. For all other modes the default values are $K_p = 0.5$, $T_i = 0.5$. See table, fig. 33. The table shows the suggested controller settings:

	κ _p			
System/application	Heating system ¹⁾	Cooling system ²⁾	Тi	
	0.5	- 0.5	10 + 5L ₂	
	-0	.5	10 + 5L ₂	
	0.5	- 0.5	30 + 5L ₂	

Fig. 33 Suggested controller settings

- Heating systems are systems in which an increase in pump performance will result in a rise in temperature at the sensor.
- ²⁾ Cooling systems are systems in which an increase in pump performance will result in a **drop** in temperature at the sensor.
- L₂ = Distance in [m] between heat exchanger and sensor.

Proceed as follows:

- Increase the gain (K_p) until the motor becomes unstable. Instability can be seen by observing if the measured value starts to fluctuate. Furthermore, instability is audible as the motor starts hunting up and down. Some systems, such as temperature controls, are slow-reacting, meaning that it may be several minutes before the motor becomes unstable.
- Set the gain (K_p) to half the value of the value which made the motor unstable. This is the correct setting of the gain.
- Reduce the integral time (T_i) until the motor becomes unstable.
- 4. Set the integral time (T_i) to twice the value which made the motor unstable. This is the correct setting of the integral time.

General rules of thumb:

- If the controller is too slow-reacting, increase Kp.
- If the controller is hunting or unstable, dampen the system by reducing $K_{\rm p}$ or increasing $T_{\rm i}.$

13.3.7 Constant curve

The pump can be set to operate according to a constant curve, like an uncontrolled pump. See fig. 34.

The desired speed can be set in % of maximum speed in the range from 25 to 100 %.





Fig. 34 Constant curve

Note

Depending on the system characteristic and the duty point, the 100 % setting may be slightly smaller than the pump's actual max. curve even though the display shows 100 %. This is due to power and pressure limitations built into the pump. The deviation varies according to pump type and pressure loss in the pipes.



Fig. 35 Power and pressure limitations influencing the max. curve

13.4 FLOW_{LIMIT}



Navigation

Home > Settings > FLOW_{LIMIT}

FLOW_{LIMIT}

- Enable FLOWLIMIT function
- Set FLOWLIMIT.

Setting:

- 2. To set the FLOW_{LIMIT}, press [OK] to start the setting.
- Select digit with < and > and adjust with < or .
- 4. Press [OK] to save.



Fig. 36 FLOW_{LIMIT}

The FLOW_{LIMIT} function can be combined with the following control modes:

- Prop. press.
- Const. press.
- Const. temp.
- Constant curve.

A flow-limiting function ensures that the flow never exceeds the entered $\mathsf{FLOW}_{\textit{LIMIT}}$ value.

The setting range for $\mathsf{FLOW}_{\mathit{LIMIT}}$ is 25 to 90 % of the Q_{\max} of the pump.

The factory setting of the $FLOW_{LIMIT}$ is the flow where the AUTO_{ADAPT} factory setting meets the max. curve. See fig. 27.

13.5 Automatic Night Setback



3.1.6.0.0.0 Automatic Night Setback

Navigation

3.1.5.0.0.0 FLOW_{LIMIT}

Home > Settings > Automatic Night Setback

Automatic Night Setback

To enable the function, select "Active" with \checkmark or \bigstar and press [OK].

Once Automatic Night Setback has been enabled, the pump automatically changes between normal duty and night setback (duty at low performance).

Changeover between normal duty and night setback depends on the flow-pipe temperature.

The pump automatically changes over to night setback when the built-in sensor registers a flow-pipe temperature drop of more than +18 to +27 °F (-8 to -3 °C) within approx. two hours.

The temperature drop must be at least 0.18 °F/min (0.1 °C/min). Changeover to normal duty takes place without a time lag when the temperature has increased by approx. +18 °F (-8 °C).



TM05 2445 1212

Automatic Night Setback cannot be enabled when the pump is in constant-curve mode.

28

English (US)



Navigation

Home > Settings > Relay outputs

Relay outputs

Relay output 1

13.6 Relay outputs

- Relay output 2.
- The relay outputs can be set to the following:
- Not active
- Readv
- Alarm
- Operation. •

The pump incorporates two signal relays, terminals 1, 2 and 3, for a potential-free alarm signal, ready signal and operating signal. For further information, see section 5.5.1 Relay outputs.

Set the function of the signal relays, alarm signal (factory setting), ready signal and operating signal, on the pump control panel.

The output, terminals 1, 2 and 3, is electrically separated from the rest of the controller.

The signal relay is operated as follows:

- Not active •
- The signal relay is deactivated.
- Ready ٠

The signal relay is active when the pump is running or has been set to stop, but is ready to run.

• Alarm

The signal relay is activated together with the red indicator light on the pump.

Operation

The signal relay is activated together with the green indicator light on the pump.

13.7 Setpoint influence



3.1.15.0.0.0 Setpoint influence

Navigation

Note

3.1.12.0.0.0 Relay outputs

Home > Settings > Setpoint influence

Setpoint influence

- · External setpoint function
- Temperature influence.

13.7.1 External setpoint function

Range		
4-20 mA	[0-100 %]	
0-10 V	[0-100 %]	
Control		
Control 0-20 %	(e.g. 0-2 V)	Setpoint = Min.

The external setpoint function is an external 0-10 V or 4-20 mA signal that will control the pump speed in a range from 0 to 100 % in a linear function. See fig. 37.



Before the "External setpoint function" can be enabled, the analog input must be set to "External setpoint influence" via the "Assist" menu.

See section 5.6 Analog input for external sensor.



Fig. 37 External setpoint function, 0-10 V

13.7.2 Temperature influence

When this function is enabled in proportional- or constant-pressure control mode, the setpoint for head will be reduced according to the liquid temperature.

Temperature influence can be set to function at liquid temperatures below +176 °F or +122 °F (80 °C or 50 °C). These temperature limits are called T_{max.}. The setpoint is reduced in relation to the head set (= 100 %) according to the characteristics below.



Fig. 38 Temperature influence

In the above example, $T_{max.}$ = +176 °F (+80 °C) has been selected.

The actual liquid temperature T_{actual} causes the setpoint for head to be reduced from 100 % to H_{actual} .

The temperature influence function requires the following:

- Proportional-pressure, constant-pressure or constant-curve control mode.
- Pump installed in flow pipe.
- System with flow-pipe temperature control. •

Temperature influence is suitable for the following systems:

- Systems with variable flows (for example two-pipe heating systems) in which the enabling of the temperature influence function will ensure a further reduction of the pump performance in periods with small heating demands and consequently a reduced flow-pipe temperature.
- Systems with almost constant flows (for example one-pipe heating systems and underfloor heating systems), in which variable heating demands cannot be registered as changes in the head as is the case with two-pipe heating systems. In such systems, the pump performance can only be adjusted by enabling the temperature influence function.

Selection of T_{max.}

In systems with a dimensioned flow-pipe temperature of:

- up to and including +131 °F (+55 °C), select $T_{max.}$ = +122 °F (+50 °C)
- above +131 °F (+55 °C), select T_{max.} = +176 °F (80 °C).



The temperature influence function cannot be used in air-conditioning and cooling systems.

13.8 Bus communication

13.8.1 Pump number



Navigation

Home > Settings > Bus communication > Pump number

Pump number

A unique number can be allocated to the pump. This makes it possible to distinguish between pumps in connection with bus communication.

13.9 General settings

13.9.1 Language



Navigation

Home > Settings > General settings > Language

Language

The display can be shown in any of the following languages: GB, BG, CZ, DK, DE, EE, GR, ES, FR, HR, IT, LV, LT, HU, NL, UA, PL, PT, RU, RO, SK, SI, RS, FI, SE, TR, CN, JP or KO. Measuring units are automatically changed according to selected language.

Setting:

- 1. Select language with \checkmark and \land .
- 2. Press [OK] to enable.

TM05 7947 1613

13.9.2 Set date and time



Navigation

Home > Settings > General settings > Set date and time

Set date and time

- Select date format
- Set date
- Select time format
- Set time.

Set the real-time clock in this menu.

Select date format

- YYYY-MM-DD
- DD-MM-YYYY
- MM-DD-YYYY.

Setting:

- 1. Select "Set date".
- 2. Press [OK] to start the setting.
- 3. Select digit with < and > and adjust with < or <.
- 4. Press [OK] to save.

Select time format

- HH:MM 24-hour clock
- HH:MM am/pm 12-hour clock.
- Setting:
- 1. Select "Set time".
- 2. Press [OK] to start the setting.
- 3. Select digit with < and > and adjust with < or .
- 4. Press [OK] to save.



Navigation

Home > Settings > General settings > Units

Units

3.1.19.2.0.0 Set date and time

- SI or US units
- Customized units.

Select whether the display should shows SI or US units or select the desired units for the parameters below.

- Pressure
- Differential pressure
- Head
- Level
- Flow rate
- Volume
- Temperature
- Differential temp.
- Power
- Energy.

Setting:

- 1. Select parameter and press [OK].
- 2. Select unit with \checkmark or \checkmark .
- 3. Press [OK] to enable.

If "SI or US units" is selected, the customized units will be reset.

3.1.19.3.0.0 Units

13.9.4 Enable/disable settings



Navigation

Home > Settings > General settings > Enable/disable settings

Enable/disable settings

In this display, the possibility of making settings can be disabled for protective reasons.

Select "Disable" with ♥ or ▲ and press [OK].

The pump will now be locked for settings. Only the "Home" display will be available.

To unlock the pump and allow settings, press \checkmark and \checkmark simultaneously for at least 5 seconds.

13.9.5 Delete history



Navigation

Home > Settings > General settings > Delete history

Delete history

- Delete work log
- Delete heat energy data
- Delete energy consumption.

It is possible to delete data from the pump, for example if the pump is moved to another system or if new data are required due to changes to the system.

Setting:

- 1. Select the relevant submenu and press [OK].
- Select "Yes" with ✓ or ▲ and press [OK] or press ⊕ to cancel.

13.9.6 Define Home display



Navigation

Home > Settings > General settings > Define Home display Define Home display

- Select Home display type
- Define Home display contents.

The "Home" display can be set to show up to four user-defined parameters or a graphical illustration of a performance curve.

Select Home display type

- 1. Select "List of data" or "Graphical illustration" with ♥ or ▲.
- 2. Press [OK] to save.

3.1.19.5.0.0 Delete history

To specify the contents, go to "Define Home display contents".

Define Home display contents

- 1. To set "List of data", press [OK] to start the setting. A list of parameters will appear in the display.
- Select or deselect with [OK]. Up to four parameters can be selected.

The selected parameters will be shown as illustrated below.

The arrow icon indicates that the parameter links to the "Settings" menu and works as a shortcut for quick settings.



- 1. To set "Graphical illustration", press [OK] to start the setting.
- 2. Select the desired curve and press [OK] to save.

13.9.7 Display brightness



Navigation

Home > Settings > General settings > Display brightness

Brightness

- 1. Press [OK] to start the setting.
- 2. Set brightness with $\boldsymbol{\boldsymbol{<}}$ and $\boldsymbol{\boldsymbol{>}}$.
- 3. Press [OK] to save.

13.9.8 Return to factory settings



Navigation

Home > Settings > General settings > Return to factory settings

Return to factory settings

It is possible to recall the factory settings and overwrite the current settings. All user settings in the "Settings" and "Assist" menus will be set back to the factory settings. This also includes language, units, possible setup of analog input, multi-pump function, etc.

To overwrite the current settings with the factory settings, select "Yes" with \checkmark or \land and press [OK].

13.9.9 Run start-up guide

🔂 Ho Status	Settings	Assist
Run start-up	guide	3.1.19.11.0.0
To return to the s	start-up guide, sei	lect "Yes"
with 🗸 or 🥆 and	i press OK.	
No		
Yes		

Navigation

3.1.19.7.1.0 Brightness

Home > Settings > General settings > Run start-up guide

Run start-up guide

It is possible to run the start-up guide again. The start-up guide will guide the user through the general settings of the pump, such as language, date and time.

To run the start-up guide, select "Yes" with \checkmark or \checkmark and press [OK].

3.1.19.11.0.0 Run start-up guide

14. "Assist" menu



Navigation

Home > Assist

Press (and go to the "Assist" menu with >.

"Assist" menu

This menu offers the following:

- Assisted pump setup
- Setting of date and time
- Multi-pump setup
- · Setup, analog input
- Description of control mode
- Assisted fault advice.

The "Assist" menu guides the user through the setting of the pump. In each submenu, the user is presented with a guide that helps throughout the setting.

14.1 Assisted pump setup

This submenu is a step-by-step guide to complete pump setup, starting with a presentation of the control modes and ending with the setpoint setting.

14.2 Setting of date and time

See section 13.9.2 Set date and time.

14.3 Multi-pump setup

This submenu assists the user in setting up a multi-pump system. See section *14.8 Multi-pump function*.

14.4 Setup, analog input

This submenu assists the user in setting up the analog input.

14.5 Description of control mode

This submenu gives a short description of each control mode.

14.6 Assisted fault advice

This submenu provides information about faults and corrective actions.

14.7 Wireless GENlair

The pump is designed for multi-pump connection via the wireless GENIair connection or wired via a bus system (Building Management System).

The built-in wireless GENIair module enables communication between pumps and with Grundfos Go Remote without the use of add-on modules:

- Multi-pump function. See section *14.8 Multi-pump function*.
- Grundfos GO Remote. See section 18.1 Grundfos GO Remote.

14.8 Multi-pump function

Assist

The multi-pump function enables the control of single-head pumps connected in parallel and twin-head pumps without the use of external controllers. The pumps in a multi-pump system communicate with each other via the wireless GENIair connection.

A multi-pump system is set up via a selected pump, i.e. the master pump (first selected pump). All Grundfos pumps with a wireless GENIair connection can be connected to the multi-pump system.

The multi-pump functions are described in the following sections.

14.8.1 Alternating operation

Only one pump is operating at a time. The change from one pump to the other depends on time or energy. If a pump fails, the other pump will take over automatically.

Pump system:

- Twin-head pump.
- Two single-head pumps connected in parallel. The pumps must be of same type and size. Each pump requires a non-return valve in series with the pump.

14.8.2 Back-up operation

One pump is operating continuously. The back-up pump is operated at intervals to prevent seizing up. If the duty pump stops due to a fault, the back-up pump will start automatically. Pump system:

Twin bood nu

- Twin-head pump.
- Two single-head pumps connected in parallel. The pumps must be of same type and size. Each pump requires a non-return valve in series with the pump.

14.8.3 Cascade operation

Cascade operation ensures that the pump performance is automatically adapted to the consumption by switching pumps on or off. The system thus runs as energy-efficiently as possible with a constant pressure and a limited number of pumps.

All pumps in operation will run at equal speed. Pump changeover is automatic and depends on energy, operating hours and fault. Pump system:

- Twin-head pump.
- Two single-head pumps connected in parallel. The pumps must be of same type and size. Each pump requires a non-return valve in series with the pump.
- The control mode must be set to "Const. press." or "Constant curve".



- Underfloor heating systems with thermostatic valves.
- One-pipe heating systems with thermostatic valves or pipe balancing valves.
- Primary circuit pumps in systems with small pressure losses in the primary circuit.



System application	Select this control mode
	Constant temperature
In heating systems with a fixed system characteristic, for example domestic hot-water systems, the control of the pump according to a constant return-pipe temperature may be relevant. FLOW _{LIMIT} can be used with advantage to control the maximum circulation flow.	
	Differential temperature
In a heating system where a constant temperature drop across the system is desired, constant differential temperature can be used. This mode requires an external temperature sensor for the second temperature measurement.	
If an external controller is installed, the pump is able to change from one constant curve to another, depending on the value of the external signal.	Constant curve

The pump can also be set to operate according to the max. or min. curve, like an uncontrolled pump:

- The max. curve mode can be used in periods in which a maximum flow is required. This operating mode is for instance suitable for hot-water priority.
- The min. curve mode can be used in periods in which a minimum flow is required. This operating mode is for instance suitable for manual night setback if Automatic Night Setback is not desired.

In systems with pumps operating in parallel.

The multi-pump function enables the control of single-head pumps connected in parallel (two pumps) and twin-head pumps without the use of external controllers. The pumps in a multi-pump system communicate with each other via the wireless GENIair connection.

"Assist" menu "Multi-pump setup"

16. Fault finding

Warning Before d

Before dismantling the pump, drain the system or close the isolating valve on either side of the pump. The pumped liquid may be scalding hot and under high pressure.

16.1 Grundfos Eye operating indications

Grundfos Eye	Indication	Cause
000000	No lights on.	Power off. Pump not running.
000000	Two opposite green indicator lights running in the direction of rotation of the pump.	Power on. Pump running.
000000	Two opposite green indicator lights permanently on.	Power on. Pump not running.
	One yellow indicator light running in the direction of rotation of the pump.	Warning. Pump running.
	One yellow indicator light permanently on.	Warning. Pump stopped.
000000	Two opposite red indicator lights flashing simultaneously.	Alarm. Pump stopped.
000000	One green indicator light in the middle permanently on (in addition to another indication).	Remote-controlled. The pump is currently being accessed by Grundfos GO Remote.

16.2 Signalling communication with remote control

The center indicator light in the Grundfos Eye will indicate communication with Grundfos GO Remote. The table below describes the desired function of the center indicator light.

Case	Description	Signalling by the center indicator light
Wink	The pump in question is highlighted in the Grundfos GO Remote display.	Four or five quick flashes once to signal "I am here".
WIIIK	indicator light will flash four or five times once to signal "I am here".	
Push me	The pump in question is selected/opened in the Grundfos GO Remote menu. The pump will signal "Push me" to ask the user to select the pump/allow the pump to exchange data with Grundfos GO Remote. The indicator light will flash continuously until a pop-up window asks the user to press [OK] to allow communication with Grundfos GO Remote.	Flashing continuously with 50 % duty cycle.
I am connected	The indicator light is signalling that the pump is connected to Grundfos GO Remote. The indicator light is permanently on as long as the pump is selected in Grundfos GO Remote.	Indicator light permanently on.

16.3 Fault finding

A fault indication can be reset in one of the following ways:

- When the fault cause has been eliminated, the pump will revert to normal duty.
- If the fault disappears by itself, the fault indication will automatically be reset.
- The fault cause will be stored in the pump alarm log.

Warning and alarm codes	Fault	Automatic reset and restart?	Corrective actions
Pump communication fault (10) Alarm	Communication fault between different parts of the electronics.	Yes	Replace the pump, or call GRUNDFOS SERVICE for assistance. Check if the pump is running in turbine operation. See code (29) Forced pumping.
Forced pumping (29) Alarm	Other pumps or sources force flow through the pump even if the pump is stopped and switched off.	Yes	Switch off the pump on the main switch. If the light in the Grundfos Eye is on, the pump is running in forced-pumping mode. Check the system for defective non-return valves and replace, if necessary. Check the system for correct position of non-return valves, etc.
Undervoltage (40, 75) Alarm	Supply voltage to the pump too low.	Yes	Check that the power supply is within the specified range.
Blocked pump (51) Alarm	The pump is blocked.	No	Dismantle the pump, and remove any foreign matter or impurities preventing the pump from rotating.
Dry running (57) Alarm	No water at the pump inlet or the water contains too much air.	No	Prime and vent the pump before a new start-up. Check that the pump is operating correctly. If not, replace the pump, or call GRUNDFOS SERVICE for assistance.
High motor temperature (64) Alarm	Temperature in stator windings too high.	No	Check the winding resistance according to the MAGNA3 service instructions.
Internal fault (72, 84, 155, 157) Warning/alarm	Internal fault in the pump electronics.	Yes	Replace the pump, or call GRUNDFOS SERVICE for assistance.
Overvoltage (74) Alarm	Supply voltage to the pump too high.	Yes	Check that the power supply is within the specified range.
Communication fault, twin-head pump (77) Warning	Communication between pump heads disturbed or broken.	Yes	Check that the second pump head is powered or connected to the power supply.
Internal sensor fault (88) Warning	The pump is receiving a signal from the internal sensor which is outside the normal range.	Yes	Check that the plug and cable are connected correctly in the sensor. The sensor is located on the back of the pump housing. Replace the sensor, or call GRUNDFOS SERVICE for assistance.
External sensor fault (93) Warning	The pump is receiving a signal from the external sensor which is outside the normal range.	Yes	Does the electrical signal set (0-10 V or 4-20 mA) match the sensor output signal? If not, change the setting of the analog input, or replace the sensor with one that matches the setup. Check the sensor cable for damage. Check the cable connection at the pump and at the sensor. Correct the connection, if required. The sensor has been removed, but the analog input has not been disabled. Replace the sensor, or call GRUNDFOS SERVICE for assistance.



If the power supply cable is damaged, it must be replaced by the manufacturer, the manufacturer's service partner or a similarly qualified person.



Fig. 39 Correct position of sensor

During maintenance and replacement of the sensor, it is important that the sealing cap is fitted correctly on the sensor housing.

Tighten the screw holding the clamp to 3.7 ft-lbs (5 Nm).



Warning Before replacing the sensor, make sure that the pump is stopped and that the system is not pressurized.

17.1 Sensor specifications

17.1.1 Pressure

Maximum differential pressure during operation	29 psi / 2 bar / 0.2 MPa
Accuracy +32 to +185 °F (0 to +85 °C)	2 %*
Accuracy +14 to +32 °F and +185 to +266 °F (-10 to 0 °C and +85 to +130 °C)	3 %*

* Full scale.

17.1.2 Temperature

Temperature range during operation	+14 to +266 °F (-10 to +130 °C)
Accuracy	± 3.6 °F (± 2 °C)

English (US)

18. Accessories



18.1 Grundfos GO Remote

MAGNA3 is designed for wireless communication with the Grundfos GO Remote app. The Grundfos GO Remote app communicates with the pump via radio communication (wireless GENIair).



The radio communication between the pump and Grundfos GO Remote is encrypted to protect against misuse.

The Grundfos GO Remote app is available from Apple AppStore and Android market.

The Grundfos GO Remote concept replaces the Grundfos R100 remote control. This means that all products supported by the R100 are supported by Grundfos GO Remote.

Grundfos GO Remote can be used for the following:

- Reading of operating data.
- Reading of warning and alarm indications.
- · Setting of control mode.
- Setting of setpoint.
- Selection of external setpoint signal.
- Allocation of pump number making it possible to distinguish between pumps that are connected via Grundfos GENIbus.
- Selection of function for digital input.
- Generation of reports (PDF).
- Assist function.
- Multi-pump setup.
- Display of relevant documentation.

For function and connection to the pump, see separate installation and operating instructions for the desired type of Grundfos GO Remote setup.

18.2 Communication

The pump can communicate via the wireless GENIair connection or a CIM module.

This enables the pump to communicate with other pumps and with different types of network solutions.

The Grundfos CIM modules (CIM = Communication Interface Module) enable the pump to connect to standard fieldbus networks.



Fig. 40 Building management system (BMS) with four pumps connected in parallel

A CIM module is an add-on communication interface module. The CIM module enables data transmission between the pump and an external system, for example a BMS or SCADA system. The CIM module communicates via fieldbus protocols.

Note

A gateway is a device that facilitates the transfer of data between two different networks based on different communication protocols.

The following CIM modules are available:

Module	Fieldbus protocol	Product number
CIM 050	GENIbus	96824631
CIM 100	LonWorks	96824797
CIM 150	PROFIBUS DP	96824793
CIM 200	Modbus RTU	96824796
CIM 250	GSM/GPRS	96824795
CIM 270	GRM	96898815
CIM 300	BACnet MS/TP	96893770
CIM 500	Ethernet	98301408

18.2.1 Description of CIM modules

Module	Fieldbus protocol	Description	Functions
CIM 050			
	GENIbus 312 1612	CIM 050 is a Grundfos communication interface module used for communication with a GENIbus network.	CIM 050 has terminals for the GENIbus connection.
CIM 100			
	LonWorks	CIM 100 is a Grundfos communication interface module used for communication with a LonWorks network.	CIM 100 has terminals for the LonWorks connection. Two LEDs are used to indicate the actual status of the CIM 100 communication. One LED is used for indication of correct connection to the pump, and the other is used to indicate LonWorks communication status.
CIM 150			
	PROFIBUS DP	CIM 150 is a Grundfos communication interface module used for communication with a PROFIBUS network.	CIM 150 has terminals for the PROFIBUS DP connection. DIP switches are used to set line termination. Two hexadecimal rotary switches are used to set the PROFIBUS DP address. Two LEDs are used to indicate the actual status of the CIM 150 communication. One LED is used for indication of correct connection to the pump, and the other is used to indicate PROFIBUS communication status.
CIM 200			CIM 200 has terminals for the Modbus connection.
	Modbus RTU 518 1915 1815 1915	CIM 200 is a Grundfos communication interface module used for communication with a Modbus RTU network.	DIP switches are used to select parity and stop bits, to select transmission speed and to set line termination. Two hexadecimal rotary switches are used to set the Modbus address. Two LEDs are used to indicate the actual status of the CIM 200 communication. One LED is used for indication of correct connection to the pump, and the other is used to indicate Modbus communication status.
CIM 250	GSM/GPRS	CIM 250 is a Grundfos communication interface module used for GSM/GPRS communication. CIM 250 is used to communicate via a GSM network.	CIM 250 has a SIM-card slot and an SMA connection to the GSM antenna. CIM 250 also has an internal backup battery. Two LEDs are used to indicate the actual status of the CIM 250 communication. One LED is used for indication of correct connection to the pump, and the other is used to indicate GSM/GPRS communication status. Note: The SIM card is not supplied with CIM 250. The SIM card from the service provider must support data/fax service to use call service from PC Tool or SCADA. The SIM card from the service provider must support GPRS service to use Ethernet service from PC Tool or SCADA.

Module	Fieldbus	Description	Functions
CIM 070	protocol		
CINE 270	Grundfos Remote Management 2572 254332 255332 25532 255332	CIM 270 is a Grundfos GSM/GPRS modem used for communication with a Grundfos Remote Management system. It requires a GSM antenna, a SIM card and a contract with Grundfos.	With CIM 270 you have wireless access to your account anywhere, anytime when you have an internet connection, for example via a smartphone, tablet PC, laptop or computer. Warnings and alarms can be sent by e-mail or SMS to your mobile phone or computer. You will get a complete status overview of the entire GRM system. It allows you to plan maintenance and service based on actual operating data.
CIM 300	BACnet MS/TP 5151 5182 5182 5004	CIM 300 is a Grundfos communication interface module used for communication with a BACnet MS/TP network.	CIM 300 has terminals for the BACnet MS/TP connection. DIP switches are used to set transmission speed and line termination and to select the custom Device Object Instance Number. Two hexadecimal rotary switches are used to set the BACnet address. Two LEDs are used to indicate the actual status of the CIM 300 communication. One LED is used for indication of correct connection to the pump, and the other is used to indicate BACnet communication status.
CIM 500			
	Ethernet	CIM 500 is a Grundfos communication interface module used for data transmission between an industrial Ethernet network and a Grundfos product.	CIM 500 supports various industrial Ethernet protocols. CIM 500 is configured via the built-in web server, using a standard web browser on a PC. See the specific functional profile on the DVD-ROM supplied with the Grundfos CIM module.

18.2.2 Grundfos Remote Management

Grundfos Remote Management is an easy-to-install, low-cost solution for wireless monitoring and management of Grundfos products. It is based on a centrally hosted database and a web server with wireless data collection via GSM/GPRS modem. The system only requires an internet connection, a web browser, a GRM modem and an antenna as well as a contract with Grundfos allowing you to monitor and manage Grundfos pump systems.

You have wireless access to your account anywhere, anytime when you have an internet connection, for example via a smartphone, tablet PC, laptop or computer. Warnings and alarms can be sent by e-mail or SMS to your mobile phone or computer.

Application	Description	Product number
CIM 270	Grundfos Remote Management (requires a contract with Grundfos and a SIM card).	96898815
GSM antenna for roof-mounting	Antenna for use on top of metal cabinets. Vandal-proof. 2-metre cable. Quad band (global use).	97631956
GSM antenna for desk-mounting	Antenna for general-purpose application, for example inside plastic cabinets. To be fixed with the double-adhesive tape supplied. 4-metre cable. Quad band (global use).	97631957

For GRM contract, contact your local Grundfos company.

18.2.3 Reuse of CIM modules

A CIM module in a CIU unit used together with GRUNDFOS MAGNA can be reused in MAGNA3.

The CIM module has to be re-configured before it is used in a MAGNA3 pump. Contact your nearest Grundfos company.



Fig. 41 Reuse of CIM module

English (US)

18.3 Fitting the CIM module



Warning

Before fitting the module, switch off the power supply. Make sure that the power supply cannot be accidentally switched on.



19. Technical data

Supply voltage

See Pump Nameplate for Rated Supply Voltage: 1 x 115 V \pm 10 %, 50/60 Hz, PE.

1 x 208-230 V ± 10 %, 50/60 Hz, PE.

Motor protection

The pump requires no external motor protection.

Enclosure class

Enclosure Type 2.

Insulation class

F.

Relative air humidity

Maximum 95 %.

Ambient temperature

+32 °F to +104 °F (0 °C to +40 °C). During transport: -40 °F to +158 °F (-40 °C to +70 °C).

Temperature class

TF110 (EN 60335-2-51).

Liquid temperature

Continuously: +14 °F to +230 °F (-10 °C to +110 °C).

Stainless-steel pumps in domestic hot-water systems:

In domestic hot-water systems, we recommend to keep the liquid temperature below +150 °F (+65 °C) to eliminate the risk of lime precipitation.

System pressure

The maximum permissible system pressure is stated on the pump nameplate:

175 psi (12 bar).

Inlet pressure

Recommended inlet pressures:

Single-head pumps:

- Min. 1.5 psi / 0.10 bar / 0.01 MPa at +167 °F (+75 °C)
- Min. 5 psi / 0.35 bar / 0.035 MPa at +203 °F (+95 °C)
- Min. 9.5 psi / 0.65 bar / 0.065 MPa at +230 °F (+110 °C).

Twin-head pumps:

- Min. 13 psi / 0.90 bar / 0.09 MPa at +167 °F (+75 °C)
- Min. 17.5 psi / 1.20 bar / 0.12 MPa at +203 °F (+95 °C)
- Min. 22 psi / 1.50 bar / 0.15 MPa at +230 °F (+110 °C).

EMC (electromagnetic compatibility)

EN 55014-1:2006, EN 55014-2:1998, EN 61800-3-3:2008 and EN 61000-3-2:2006.

Sound pressure level

The sound pressure level of the pump is lower than 43 dB(A).

Leakage current

The pump mains filter will cause a discharge current to earth during operation. $I_{leakage}$ < 3.5 mA.

Consumption when the pump is stopped

1 to 10 W, depending on activity, i.e. reading the display, use of Grundfos GO Remote, interaction with modules, etc.

Input/output communication

Two digital inputs	External potential-free contact. Contact load: 5 V, 10 mA. Screened cable. Loop resistance: Maximum 130 Ω.
Analog input	4-20 mA (load: 150 Ω). 0-10 VDC (load: 78 kΩ).
Two relay outputs	Internal potential-free changeover contact. Maximum load: 250 V, 2 A, AC1. Minimum load: 5 VDC, 20 mA. Screened cable, depending on signal level.

cos φ

MAGNA3 has a built-in active PFC (Power Factor Correction) which gives a cos ϕ from 0.98 to 0.99, i.e. very close to 1.

20. Disposal

This product has been designed with focus on the disposal and recycling of materials. The following disposal values apply to all variants of Grundfos MAGNA3 pumps:

- minimum 85 % recycling
- maximum 10 % incineration
- maximum 5 % depositing.

Values in percent of total weight.

This product or parts of it must be disposed of in an environmentally sound way according to local regulations.

Subject to alterations.

GRUNDFOS Kansas City 17100 West 118th Terrace Olathe, Kansas 66061 Phone: (913) 227-3400 Fax: (913) 227-3500

www.grundfos.us

GRUNDFOS Canada 2941 Brighton Road Oakville, Ontario L6H 6C9 Canada Phone: +1-905 829 9533 Telefax: +1-905 829 9512

www.grundfos.ca

GRUNDFOS México Boulevard TLC No. 15 Parque Industrial Stiva Aeropuerto C.P. 66600 Apodaca, N.L. México Phone: 011-52-81-8144 4000 Fax: 011-52-81-8144 4010

www.grundfos.mx

L-MAG-TL-09

98459408 0614 ECM: 1133339



www.grundfos.com







Additional operating modes for multi-pump setup

Multi-pump function

The multi-pump function enables the control of single-head pumps connected in parallel and twin-head pumps without the use of external controllers. The pumps in a multi-pump system communicate with each other via the wireless GENIair connection.

A multi-pump system is set up via a selected pump, i.e. the master pump (first selected pump). The multi-pump functions are described in the following sections.

Alternating operation

Only one pump is operating at a time. The change from one pump to the other depends on time or energy. If a pump fails, the other pump will take over automatically. Pump system:

- · Twin-head pump.
- Two single-head pumps connected in parallel. The pumps must be of equal size and type. Each pump requires a non-return valve in series with the pump.

Back-up operation

One pump is operating continuously. The back-up pump is operated at intervals to prevent seizing up. If the duty pump stops due to a fault, the back-up pump will start automatically.

Pump system:

- Twin-head pump.
- Two single-head pumps connected in parallel. The pumps must be of equal size and type. Each pump requires a non-return valve in series with the pump.

Cascade operation

Cascade operation ensures that the pump performance is automatically adapted to the consumption by switching pumps on or off. The system thus runs as energy-efficiently as possible with a constant pressure and a limited number of pumps.

The back-up of a twin-head pump will start at 90 % and stop at 50 % performance when operating in constant-pressure mode.

It can be advantageous to choose a twin-head pump, as the back-up pump will start for a short period in peak-load situations. If an oversized single-head pump is chosen, it may run outside its best efficiency range most of the time.

All pumps in operation will run at equal speed. Pump changeover is automatic and depends on speed, operating hours and fault.

Pump system:

- Twin-head pump.
- Two single-head pumps connected in parallel. The pumps must be of equal size and type. Each pump requires a non-return valve in series with the pump.
- The control mode must be set to "Const. press." or "Constant curve".

Readings and settings on the pump

Control panel and display

The MAGNA3 pump features a 4" TFT display with intuitive and user-friendly interface. The control panel has self-explanatory push-buttons made of high-quality silicone for precise navigation in the menu structure. The control panel is designed to give the user quick and easy access to pump and performance data on site.

When the pump is started up for the first time, the user is presented with a start-up guide enabling easy setting of the pump. Additionally, the "Assist" menu can guide the user through the various settings of the pump.



Fig. 23 Control panel

Button	Function
۲	Goes to the "Home" menu.
۲	Returns to the previous action.
< >	Navigates between main menus, displays and digits. When the menu is changed, the display will always show the top display of the new menu.
~~	Navigates between submenus.
©K)	Saves changed values, resets alarms and expands the value field.

9. Product numbers

MAGNA3

	Cast	iron	Stainles	ss steel
Single-head pump	115 V	208-230V	115 V	208-230V
MAGNA3 40-80 F (N)	98126800	98126828	98126802	98126830
MAGNA3 40-120 F (N)	98126804	98126832	98126806	98126834
MAGNA3 40-180 F (N)	98126808	98126836	98126810	98126838
MAGNA3 50-80 F (N)	98126812	98126840	98126814	98126842
MAGNA3 50-150 F (N)	98126816	98126844	98126818	98126846
MAGNA3 65-120 F (N)	98124696	98124696	98124702	98126850
MAGNA3 65-150 F (N)		98126852		98126854
MAGNA3 80-100 F (N)		98126856		98126858
MAGNA3 100-120 F (N)		98126860		98126862
	Cast	t iron	Stainle	ss steel
Single-head pump	115 V	208-230V	115 V	208-230V
MAGNA3 D 65-150 F		98126863		
MAGNA3 D 80-100 F		98126864		
MAGNA3 D 100-120 F		98126865		

External sensors

Sensor		Туре	Measuring range °F [°C]		Power supply [VDC]	Transmitt output [m	ter Pr na] con	ocess nection	Product number
			00 1 0 10 15 (00 1	400.001	44.4- 00	4 4= 20	G	/2G1/2	98477669
External Ter	nperature K	at DPI + I	-22 to 248 °F [-30 to	120 °C]	11 to 30	4 to 20	GV	GG1/4	98477668
Sensor	Туре	Measuring range psi	Measuring range [bar]	Transmi [I	tter output nA]	Power supply [VDC]	Process connection	Pro	duct number
		0 - 9	[0 - 0.6]						96611522
Pressure		0 - 14	[0 - 1.0]			10 4+ 00	0.1/0		96611523
transmitter	RPI —	0 - 23	[0 - 1.6]	4	10 20	12-10-30	G 1/2		96611524
		0 - 36	[0 - 2.5]						96611525

Blanking flange

A blanking flange is used to blank off the opening when one of the pumps of a twin-head pump is removed for service to enable uninterrupted operation of the other pump.

Blanking flange	Product number	
All pumps	98159372	